



Telegram

1974 JUN 24 PM 4:20

VEA240(1654)(1-033993C175)PD 06/24/74 1651

ICS IPMVEIB MVN

02076 IDVE MORRIS IL 93 06-24 233P CDT

PMS JAMES G KEPPLER

REGIONAL DIRECTOR

DIRECTORATE OF REGULATORY OPERATIONS

REGION 3 WUX

US ATOMIC ENERGY COMMISSION

799 ROOSEVELT RD

GLEN ELLYN IL 60137

TELEGRAMS OTHER THAN MONEY ORDERS)
(YES-AGENT, NO-ADDRESSEE)
Is PHYSICAL DELIVERY requested? _____
ADDRESS SECTION
Nbr. & Name _____
Date did _____ Time did 1044a To _____ By _____
3/2-858-2660
To be mailed or filed _____
Attempts to deliver (Indicate DA or BY) _____

SUBJECT DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3

THIS WILL CONFIRM A CONVERSATION WITH F MAURA OF YOUR OFFICE AT
9 O'CLOCK AM THIS DATE CONCERNING A FAILURE OF THE AIR SUPPLY
TO THE FEED WATER REGULATING VALVE THAT OCCURRED JUNE 23, 1974

8305240040 740612
PDR ADDCK 05000237
PDR



Telegram

AT 1014 PM THIS FAILURE STARTED A CHAIN OF EVENTS THAT CAUSED SEVERE VIBRATIONS AND DAMAGE TO PIPE HANGERS AND SUPPORTS AN ORDERLY SHUT DOWN OF THE REACTOR WAS INITIATED, THE REACTOR WAS SUB CRITICAL AT 7 O'CLOCK AM

B B STEPHENSON SUPERINTENDENT
DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON CO
ROUTE 1
MORRIS IL 60450

NNNN

JUN 26 1974