



Telegram

VEE 190(1535)(1-027554C157)PD 06/06/74 1534

1974 JUN -6 PM 2:35

ICS IPMVEIB MVN

02167 NL TDVE MORRIS IL 100 06-06 136P CDT

PMS MR JAMES G KEPPLER

REGIONAL DIRECTOR

CW

312-858-2660

DIRECTORATE OF REGULATORY OPERATIONS (Indicate DA or BY)

REGION 3

WUX

US MATOMIC COMMISSION (Indicate DA or BY)

799 ROOSEVELT ROAD

GLEN ELLYN ILLINOIS 60137

SUPJECT DPR-25 DREDEN NUCLEAR POWER STATION UNIT 3

THIS WILL CONFIRM A CONVERSATION WITH F MAURA OF YOUR OFFICE AT

1330 HOURS THIS DATE CONCERNING A FAILURE TO OPEN HPCI STEAM

ISOLATION VALVE M03-2301-3 WHILE OPERATING THE REACTOR AT 180 PSIG

3305240105 740606
BDR ADDCK 05000249
PDR



Telegram

A MONTHLY HPCI SERVALANCE TEST WAS UNDER WAY WHEN THE M03-2301-3
FAILD TO OPEN WHEN GIVEN AN OPEN SIGNAL FROM THE CONTROL ROOM
ADDITIONAL DETAILS AND CORRECTIVE ACTION ARE FORTHCOMING IN THE
FORM OF A TEN DAY LETTER IN ACCORDANCE WITH SECTION 6.6.B.1A
OF THE TECHNICAL SPECIFICATIONS

B B STEPHENSON SUPT DREDEN NUCLEAR STATION
COMMONWEALTH EDISON CO
RRI MORRIS IL

NNNN

JUN 1 1 1974