

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Vermont Yankee Nuclear Power Station										DOCKET NUMBER (2) 0 5 0 0 0 2 7 1 1				PAGE (3) 1 OF 0 2							
TITLE (4) Environmental Sampling Analysis Not Performed																					
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)											
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)								
0	4	1	2	8	4	8	4	0	0	3	0	0	0	5	8	4	0	5	0	0	0
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 8: (Check one or more of the following) (11)																			
N		20.402(b)				20.406(c)				50.73(a)(2)(iv)				73.71(b)							
POWER LEVEL (10)		20.406(a)(1)(i)				50.38(a)(1)				50.73(a)(2)(v)				73.71(c)							
1 1 0 0		20.406(a)(1)(ii)				50.38(a)(2)				50.73(a)(2)(vii)				OTHER (Specify in Abstract below and in Text, NRC Form 365A)							
		20.406(a)(1)(iii)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(A)											
		20.406(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)											
		20.406(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(x)											
LICENSEE CONTACT FOR THIS LER (12)																					
NAME										TELEPHONE NUMBER											
James P. Pelletier, Plant Manager										AREA CODE 8 10 12 2 5 1 7 1 7 1 1 1											
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																					
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS											
SUPPLEMENTAL REPORT EXPECTED (14)												EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR					
YES (If yes, complete EXPECTED SUBMISSION DATE)												X NO									

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

For the period of 3/13/84 to 3/20/84, weekly air particulate and charcoal samples were taken as required by Tech Spec Sec. 4.9.D.2 and Table 3.9.1. The samples were prepared for shipment to the analytical laboratory, but were never received. Investigation indicates that the samples were mistakenly discarded as rubbish.

A review of the records for the weeks prior to and following the missed analysis did not reveal any reason to suspect other than normal readings.

8405150107 840511
PDR ADOCK 05000271
S PDR

TE22

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES 8/31/85

FACILITY NAME (1) Vermont Yankee	DOCKET NUMBER (2) 0500027184	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		84	003	00	02	OF	02

TEXT (If more space is required, use additional NRC Form 366A's) (17)


For the period of 3/13/84 to 3/20/84, weekly air particulate and charcoal samples were taken as required by Tech Spec Sec. 4.9.D.2 and Table 3.9.1. The samples were prepared for shipment to the analytical laboratory, but were never received. Investigation indicates that the samples were mistakenly discarded as rubbish. The plant was operating at 100% power, steady state and no major plant evolutions were in progress.

The samples were obtained and prepared for shipment to the analytical laboratory by placing them within a tie-top, opaque waste basket liner poly bag. It is assumed that the bag was later mistakenly thrown out by janitorial personnel cleaning the area.

A review of the records for the weeks prior to and following the missed analysis did not reveal any reason to suspect other than normal readings.

Janitorial and plant personnel will be instructed to discard only that waste present in the wastebasket in the area where the samples are stored prior to shipment. Also, care will be taken to adequately mark the sample bags to avoid confusion.

Based on the above, there were no adverse consequences to the public health and safety. No previous similar occurrences have been reported.



VERMONT YANKEE NUCLEAR POWER CORPORATION

P. O. BOX 157
GOVERNOR HUNT ROAD
VERNON, VERMONT 05354

VYV 84-211

May 11, 1984


U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

REFERENCE: Operating License DPR-28
Docket No. 50-271
Reportable Occurrence No. LER 84-03

Dear Sirs:

As defined by 10CFR50.73, we are reporting the attached Reportable Occurrence as LER 84-03.

Very truly yours,


for James P. Pelletier
Plant Manager

RDP/drc

cc: Regional Administrator
USNRC Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

IER2
11