

MGMCGBB CGO  
2-041808E149 05/29/74  
ICS IPMBNGZ CSP  
3122422734 MGM TDBN MORRIS IL 100 05-29 0615P EDT  
ZIP 60137



Mailgram



JAMES G KEPPLER REGIONAL DIRECTOR  
DIRECTORATE OF REGULATORY OPERATIONS REGION 3 US ATOMIC ENERGY  
COMMISSION 799 ROOSEVELT RD  
GLEN ELLYN IL 60137

SUBJECT DPR-19 DRESDEN NUCLEAR POWER STATION UNIT TWO THIS WILL  
CONFIRM A CONVERSATION WITH MR W FISHER OF YOUR OFFICE AT 1610  
HOURS THIS DATE CONCERNING ACTIVITY LEVELS IN AN ABOVE GROUND  
STORAGE TANK IN EXCESS OF 0.7 CURIES AS REQUIRED BY SECTION  
3.8.D OF THE TECHNICAL SPECIFICATIONS THE TANK WERE NOT REPROCESSED  
TO A BELOW GROUND STORAGE TANK WITHIN 24 HOURS THE A WASTE SAMPLE  
TANK CONTAINED 1.04 CURIES WHEN FILLED AT 1504 HOURS ON 5-27-74  
DUE TO INABILITY TO REPROCESS THIS WATER DUE TO IMPROPER FILTER  
PERFORMANCE IT WAS THEN TRANSFERED TO ANOTHER ABOVE GROUND TANK  
IE THE WASTE SURGE TANK WHICH ADDITIONALLY EXCEEDED LIMITS (1.04  
CURIES) EFFORTS ARE PRESENTLY IN PROGRESS TO IMPROVE FILTERING  
PROFORMANCE FURTHER INFORMATION WILL FOLLOW IN A TEN DAY REPORT  
B B STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION  
COMMONWEALTH EDISON CO RURAL ROUTE 1 MORRIS ILLINOIS 60450

2102 EDT

MGMCGBB CGO

MAY 30 1974

*Handwritten signature and date: 5-28-74*

8305240148 740606  
PDR ADOCK 05000237  
S PDR

MGMCGBA CGO  
2-014716E147 05/27/74  
ICS IPMBNGZ CSP  
3122422734 MGM TDBN MORRIS IL 138 05-27 0557P EDT  
ZIP 60137



Mailgram



JAMES G KEPPLER REGIONAL DIRECTOR  
DIRECTORATE OF REGULATORY OPERATIONS REGION 3 US ATOMIC ENERGY  
COMMISSION 799 ROOSEVELT RD  
GLENN ELLEN IL 60137

SUBJECT DPR19 DRESDEN NUCLEAR POWER STATION UNIT 2 THIS WILL  
CONFIRM A CONVERSATION WITH MR OGG OF YOUR OFFICE AT 1620 HOURS  
THIS DATE CONCERNING ACTIVITY LEVEL IN AN ABOVE GROUND STORAGE  
TANK IN EXCESS OF 0.7 CURIES AS REQUIRED BY SECTION 3.8.D OF  
THE TECHNICAL SPECIFICATIONS THE TANK WAS NOT RECYCLED TO A  
BELOW GROUND PROCESSING TANK WITHIN THE REQUIRED TIME PERIOD  
OF 24 HOURS THE WASTE SURGE TANK CONTAINED 1.08 CURIES WHEN  
FILLED TO A 65 PERCENT LEVEL AT 2140 HOURS ON 5-23-74 SUBSEQUENT  
PROCESSING DID NOT BRING THE ACTIVITY WITHIN SPECIFICATIONS  
UNTIL 0445 HOURS ON 5-27-74 FURTHER INFORMATION WILL FOLLOW  
THIS NOTIFICATION IN A TEN DAY REPORT

9 8 STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION  
COMMONWEALTH EDISON CO RR 1 MORRIS IL 60450

1759 EDT

MGMCGBA CGO

RECEIVED

1974 JUL 8 AM 10 57

U.S. ATOMIC ENERGY COM.  
DIVISION OF COMPLIANCE

MAY 28 1974

*Handwritten signature and date: 5-23-74*