

gram western union Telegram

WU KVN ILL

Q;

WU AGCY WHEA

WHA090 MT 430PM CDT

1974 MAY 28 AM 9 47

VEB189 1629) 2-013052E147) PD 05/27/74 1628

ICS IPHENGZ CSP

8159422920 TDDN MORRIS IL 77 05-27 0428P EDT

FMS JAMES G KEPPLER, REGIONAL DIRECTOR, DLR

DIRECTORATE OF REGULATORY OPERATIONS REGION 3 US ATOMIC ENERGY

COMMISSION 799 ROOSEVELT RD

ELLYN ILL 60137

SUBJECT DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2

THIS WILL CONFIRM A CONVERSATION WITH W OGG OF YOUR OFFICE AT

1430 OLIVE THIS DATE CONCERNING INOPERABILITY OF 2/3 DIESEL

GENERATOR AT 0800 THIS DATE SHIFT SUPERVISOR DECLARED 2/3 DIESEL

GENERATOR INOPERABLE WHEN HE NOTED THAT LOAD WAS UNSTABLE AND

MACHINE COULD NOT BE LOADED TO FULL LOAD. INITIATED REQUIRED

SURVEILLANCE FOR INOPERABLE DIESEL AND BEGAN INVESTIGATION

3 B STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION

COMMONWEALTH EDISON COMPANY RURAL ROUTE 1 MORRIS IL 60450

NNNN

WU KVN ILL

Q;

WU AGCY WHEA

MAY 28 1974

Handwritten signature and date: 5-28-74

WU MVN ILL

Q:

WU AGCY WHEA

WUAC90 MT 430PM CDT

VER189 1629) 2-013052E147) PD 05/27/74 1628

ICS IPMBNGZ CSP

M159422920 TDBN MORRIS IL 77 05-27 0428P ED1

FMS JAMES G KEPPLER, REGIONAL DIRECTOR, DLR
DIRECTORATE OF REGULATORY OPERATIONS REGION 3 US ATOMIC ENERGY
COMMISSION 799 ROOSEVELT RD
GLEN ELLYN IL 60137

SUBJECT DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2
THIS WILL CONFIRM A CONVERSATION WITH W OGG OF YOUR OFFICE AT
1430 OLIVE THIS DATE CONCERNING INOPERABILITY OF 2/3 DIESEL
GENERATOR AT 0830 THIS DATE. SHIFT SUPERVISOR DECLARED 2/3 DIESEL
GENERATOR INOPERABLE WHEN HE NOTED THAT LOAD WAS UNSTABLE AND
MACHINE COULD NOT BE LOADED TO FULL LOAD. INITIATED REQUIRED
SURVEILLANCE FOR INOPERABLE DIESEL AND BEGAN INVESTIGATION

B B STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON COMPANY RURAL ROUTE 1 MORRIS IL 60450

NNNN

WU MVN ILL

Q:

WU AGCY WHEA

MAY 28 1974

~~81434344~~

Handwritten signature and date 5/28/74

gram western union Telegram