



Telegram

TELEGRAMS (OTHER THAN MONEY ORDERS)  
Is PHYSICAL DELIVERY 1974 MAY 22 PM 5:21  
AGENT SECTION

VEB259(1807)(1-3585010142) PD 05/22/74 1804  
ICS IPMVEIA MVN  
01271 TDVE MORRIS IL 154 05-22-221P (Indicate DA or BY)  
PMS JAMES G KEPPLER REGIONAL DIRECTOR DIRECTORATE OF REGULATORY  
OPERATION REGION 3 WUX US ATOMIC ENERGY COMMISSION

799 ROOSEVELT ROAD  
GLEN ELLYN IL 60137  
SUBJECT DPR-13 DRESDEN NUCLEAR POWER STATION UNIT 2  
THIS WILL CONFIRM A CONVERSATION WITH F MAURA OF YOUR OFFICE  
AT 1350 HOURS THIS DATE CONCERNING THE FAILURE IN THE CLOSED  
POSITION OF MAIN STEAMLINE DRAIN VALVE MO-2-220-2  
ON MAY 22 1974 AT 4AM DURING POST MODIFICATION FUNCTIONAL  
TESTING THE VALVE WOULD NOT OPEN FROM THE CONTROL ROOM WHEN  
GIVEN AND OPEN SIGNAL WITH THE CONTROL SWITCH THE ISOLATION VALVE  
IN SERIES WITH THE FAILED VALVE WAS VERIFIED AND LOGGED IN THE  
CLOSED POSITION IN ACCORDANCE WITH THE TECHNICAL SPECIFICATION

W/C. Da 304p  
May 27  
da  
755A

5-237

9305240181 740617  
PDR ADOCK 05000237  
PDR



**Telegram**

AND MAINTENANCE IS TROUBLE SHOOTING THE PROBLEM DETAILS AND  
CORRECTIVE ACTION WILL BE FORWARDED IN THE FORM OF A TEN DAY LETTER  
IN ACCORDANCE WITH SECTION 6.6..B.1.A OF THE TECHNICAL  
SPECIFICATIONS

B B STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION  
COMMONWEALTH EDISON COMPANY ROUTE 1 MORRIS IL 60450

NNNN

MAY 30 1974