



**Duquesne Light**

Nuclear Division  
P.O. Box 4  
Shippingport, PA 15077-0004

Telephone (412) 393-6000

May 7, 1984

Director of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Attn: Mr. Steven A. Varga, Chief  
Operator Reactors Branch No. 1  
Division of Licensing  
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
Proposed Change Request No. 86 Revision 2  
to Operating License

Gentlemen:

Enclosed are:

1. Three (3) originals and thirty-seven (37) copies of our Application for Amendment to our Operating License DPR-66 to revise the air lock surveillance requirements to reflect the addition of the emergency air lock installed by DCP-210. Specific requirements applicable to the emergency air lock have been incorporated to reflect the design differences between the personnel air lock and the emergency air lock. The emergency air lock door seals will be tested at a pressure of greater than or equal to 10 psig and the door shaft seals will be tested at least once per 18 months during shutdown. Therefore, please remove page 3/4 6-5a from our previous submittal and replace it with the revised page, attached.
2. Forty (40) copies of documents designated Attachments A and B which set forth the change in Technical Specifications and its safety evaluation.

Since this is a revision to a previous submittal for which a Class II fee was remitted in accordance with 10 CFR 170.22, we have determined that no additional fees are required.

Very truly yours,

J. J. Carey  
Vice President, Nuclear

Adol  
1/1

8405150335 840507  
PDR ADOCK 05000334  
PDR

Beaver Valley Power Station Unit No. 1  
Docket No. 50-334, License No. DPR-66  
Proposed Change Request No. 86 Revision 2  
to Operating License  
Page 2

RNI/jas

cc: Mr. Thomas M. Gerusky, Director  
Bureau of Radiation Protection  
Pennsylvania Department of Environmental Resources  
P. O. Box 2063  
Harrisburg, PA 17120

Mr. W. M. Troskoski, Resident Inspector  
U.S. Nuclear Regulatory Commission  
Beaver Valley Power Station  
Shippingport, PA 15077

U.S. Nuclear Regulatory Commission  
c/o Document Management Branch  
Washington, DC 20555

Director, Safety Evaluation & Control  
Virginia Electric & Power Company  
P. O. Box 2666  
One James River Plaza  
Richmond, VA 23261