

OPERATING DATA REPORT

DOCKET NO. 50-244
DATE April 4, 1983
COMPLETED BY Andrew E. McNamara
TELEPHONE 1 (315) 524-4446
Ext. 301 at Ginna

OPERATING STATUS

- 1. Unit Name: GINNA STATION, UNIT #1
- 2. Reporting Period: March, 1983
- 3. Licensed Thermal Power (MWt): 1520
- 4. Nameplate Rating (Gross MWe): 490
- 5. Design Electrical Rating (Net MWe): 470
- 6. Maximum Dependable Capacity (Gross MWe): 490
- 7. Maximum Dependable Capacity (Net MWe): 470
- 8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes The reactor power level was maintained at 100% for the majority of the time until the unit was removed from service on 3/26 for annual A, I & O

- 9. Power Level to Which Restricted, If Any (Net MWe):
- 10. Reasons For Restrictions, If Any:

| | This Month | Yr.-to-Date | Cumulative |
|---|------------|-------------|-------------|
| 11. Hours In Reporting Period | 744.0 | 2,160.00 | 116,976.00 |
| 12. Number of Hours Reactor Was Critical | 602.05 | 2,001.08 | 88,887.23 |
| 13. Reactor Reserve Shutdown Hours | 0 | 0 | 1,631.32 * |
| 14. Hours Generator On-Line | 601.75 | 1,998.00 | 86,978.13 |
| 15. Unit Reserve Shutdown Hours | 0 | 0 | 8.5 * |
| 16. Gross Thermal Energy Generated (MWH) | 906,408 | 2,921,472 | 119,504,026 |
| 17. Gross Electrical Energy Generated (MWH) | 296,236 | 955,257 | 38,922,054 |
| 18. Net Electrical Energy Generated (MWH) | 281,707 | 907,546 | 36,893,608 |
| 19. Unit Service Factor | 80.88% | 92.50% | 74.36% |
| 20. Unit Availability Factor | 80.88% | 92.50% | 74.36% |
| 21. Unit Capacity Factor (Using MDC Net) | 80.56% | 89.39% | 69.00% |
| 22. Unit Capacity Factor (Using DER Net) | 80.56% | 89.39% | 69.00% |
| 23. Unit Forced Outage Rate | 0% | .97% | 8.38% |

- 24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):
None.

- 25. If Shut Down At End Of Report Period, Estimated Date of Startup: 6/7/83
- 26. Units In Test Status (Prior to Commercial Operation):

| | | |
|----------------------|----------|----------|
| | Forecast | Achieved |
| INITIAL CRITICALITY | _____ | _____ |
| INITIAL ELECTRICITY | _____ | _____ |
| COMMERCIAL OPERATION | _____ | _____ |

* Cumulative Total commencing January 1, 1975

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
 UNIT #1, Ginna Station
 DATE April 4, 1983
 COMPLETED BY Andrew E. McNamara
 Andrew E. McNamara
 TELEPHONE 1 (315) 524-4446
Ext. 301 at Ginna

MONTH March, 1983

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

| | |
|-----|------------|
| 1. | <u>472</u> |
| 2. | <u>472</u> |
| 3. | <u>471</u> |
| 4. | <u>473</u> |
| 5. | <u>473</u> |
| 6. | <u>473</u> |
| 7. | <u>473</u> |
| 8. | <u>472</u> |
| 9. | <u>472</u> |
| 10. | <u>472</u> |
| 11. | <u>471</u> |
| 12. | <u>471</u> |
| 13. | <u>471</u> |
| 14. | <u>470</u> |
| 15. | <u>471</u> |
| 16. | <u>472</u> |

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

| | |
|-----|------------|
| 17. | <u>471</u> |
| 18. | <u>471</u> |
| 19. | <u>472</u> |
| 20. | <u>473</u> |
| 21. | <u>473</u> |
| 22. | <u>471</u> |
| 23. | <u>472</u> |
| 24. | <u>471</u> |
| 25. | <u>411</u> |
| 26. | <u>95*</u> |
| 27. | <u>0</u> |
| 28. | <u>0</u> |
| 29. | <u>0</u> |
| 30. | <u>0</u> |
| 31. | <u>0</u> |

* Unit shutdown @ 0145 on 3/26.

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH March, 1983

DOCKET NO. 50-244

UNIT NAME #1, Ginna Station

DATE April 4, 1984

COMPLETED BY Andrew E. McNamara
Andrew E. McNamara

TELEPHONE 1 (315) 524-4446
Ext. 301

| No. | Date | Type 1 | Duration (Hours) | Reason 2 | Method of Shutting Down Reactor 3 | Licensee Event Report # | System Code 4 | Component Code 5 | Cause & Corrective Action to Prevent Recurrence |
|-----|----------|--------|------------------|----------|-----------------------------------|-------------------------|---------------|------------------|---|
| 2 | 03/26/83 | S | Not Avail. | B,C | 1 | ----- | --- | --- | Unit shutdown at approximately 0145 on 03/26/83 for annual inspection, refueling and maintenance. |

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit I - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
 UNIT Ginna Station, Unit #1
 DATE April 4, 1983
 COMPLETED BY Andrew E. McNamara
 Andrew E. McNamara

TELEPHONE 1 (315) 524-4446
 EXT. 301 at Ginna

MONTH March, 1983

The reactor power level was maintained at the 100% level for the majority of the report period, with the exception of minor reductions to ~ 97% on 3/18 and 3/22 to perform Periodic Tests on the Auxiliary Feedwater System.

On 3/26 the unit was removed from service for the annual inspection, maintenance and Refueling Shutdown.

GINNA STATION

Maintenance Report Summary

March, 1983

During March, routine maintenance and inspections were completed. Major safety-related maintenance included:

1. Replacement of a broken valve diaphragm on FCV-1108, Flow Control valve from the Boric Acid Blender to the Charging System.
2. Maintenance support for the scheduled Refueling Outage which commenced on 3/26/83.
3. Repairs to the Plant Ventilation Duct which was found leaking excessively.



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649



TELEPHONE
AREA CODE 716 546-2700

GINNA STATION
April 4, 1983

Director, Office of Management Information and Program Analysis
U.S. NUCLEAR REGULATORY COMMISSION
Washington, DC 20555

Subject: Monthly Report for March, 1983
Operating Status Information
R. E. Ginna Nuclear Power Plant Unit No. 1
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of March, 1983

Very truly yours,

Bruce A. Snow
Plant Superintendent

BAS/kdg

Attachments

cc: Mr. Ronald C. Haynes NRC (1)

IE24
11