

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Washington Nuclear Project - Unit 2										DOCKET NUMBER (2) 0 5 0 0 0 3 9 7					PAGE (3) 1 OF 0 2											
TITLE (4) 10CFR50 Appendix "R" Cable Fire Protection																										
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)																
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)													
0	4	1	2	8	4	8	4	0	3	1	0	0	0	5	1	0	8	4	0	5	0	0	0	0	0	0
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)																								
2		20.402(b)				20.405(c)				50.73(a)(2)(iv)				73.71(b)												
POWER LEVEL (10)		0 0 1				20.405(a)(1)(i)				50.73(a)(2)(v) (A)				73.71(c)												
		20.405(a)(1)(ii)				50.36(c)(1)				50.73(a)(2)(vii)				OTHER (Specify in Abstract below and in Text, NRC Form 365A)												
		20.405(a)(1)(iii)				50.36(c)(2)				50.73(a)(2)(viii)(A)																
		20.405(a)(1)(iv)				50.73(a)(2)(i)				50.73(a)(2)(viii)(B)																
		20.405(a)(1)(v)				50.73(a)(2)(ii)				50.73(a)(2)(ix)																
						50.73(a)(2)(iii)																				
LICENSEE CONTACT FOR THIS LER (12)																										
NAME L. D. Kassakatis, Plant Compliance Engineer										TELEPHONE NUMBER 5 0 9 3 7 7 - 1 2 5 0 1																
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13) Ext. 2201																										
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC																
B	E B	C B L				B	B I	C B L																		
B	B O	C B L				B	V A	C B L																		
SUPPLEMENTAL REPORT EXPECTED (14)												EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR										
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)												<input checked="" type="checkbox"/> NO														

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

While performing a review and update of the WNP-2 Appendix "R" Safe Shutdown Analysis, Ten (10) cables required for safe plant shutdown following a fire were identified as unprotected from the fire, i.e. no thermolag fire protection material had been applied to these cables. These cables may have been left out of the original analysis because of recent design modifications or they could have been inadvertently left out.

Thermolag coating is being added to the raceways routing these cables.

8405160257 840510
PDR ADOCK 05000397
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES: 8/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
Washington Nuclear Project - Unit 2	0 5 0 0 0 3 9 7 8 4	—	0 3 1	—	0 0	0 2	OF 0 2

TEXT (If more space is required, use additional NRC Form 365A's) (17)

- (a) Power level \approx 1%
- (b) Plant Mode - 2
- (c) During initial power operations

Review and update of the original 10CFR50 Appendix "R" Safe Shutdown Analysis identified a total of ten (10) cables which connected circuits necessary for safe plant shutdown that should have been protected (cable raceways covered with Thermolag fire protection coating) from an exposure fire but were not. Nine (9) of the cables were added after the original analysis was complete. One cable was inadvertently missed by the original analysis.

Failure to protect these cables could have resulted in the loss of ability to safely shutdown the plant following a fire. These cables provided necessary indication and control for the Diesel Generator, Standby Service Water, Residual Heat Removal, and Reactor Bldg. HVAC systems.

Thermolag fire protection coatings will be added to the raceways routing these cables.

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397
May 10, 1984


Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: **NUCLEAR PROJECT NO. 2**
LICENSEE EVENT REPORT NO. 84-031

Dear Sir:

Transmitted herewith is Licensee Event Report No. 84-031 for WNP-2 Plant. This report is submitted in response to the report requirements of Technical Specification Section 6.9.1.7 and discusses the item of noncompliance, corrective action taken, and action taken to preclude recurrence.

Very truly yours,


J. D. Martin (M/D 927M)
WNP-2 Plant Manager

JDM:de

Enclosure:
Licensee Event Report No. 84-031

cc: Mr. John B. Martin, Administrator
Region V, Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
1450 Maria Lane
Walnut Creek, California 94596
Mr. A. D. Toth, NRC Resident Inspector (90A)
Ms. Dottie Sherman
American Nuclear Insurers
The Exchange Suite 245
270 Farmington Ave.
Farmington, CT 06032

IE-22
1/1