

James G. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Telecopied Date 12-4-75
or
Telegraphed: GE 2:12 p.m.
DC _____
By KC

cc:

Bernard C. Rusche, Director
Directorate of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

50-249

SUBJECT: DPR-25, Dresden Nuclear Power Station, Unit 3.

This will confirm a conversation with MR. P. JOHNSON of
your office at 1400 hrs this date concerning INSTRUMENT SETPOINT
SHIFT OF INTERMEDIATE RANGE MONITOR #12 TO ABOVE
TECH SPEC LIMITS ($\leq 120/125$ SCALE). THE SETPOINT WAS
IMMEDIATELY RETURNED TO 120% FROM THE "AS FOUND"
SETTING OF 121%. ALL OTHER INSTRUMENTATION WAS
OPERABLE AT THE TIME TO PROVIDE FOR MINIMUM INSTRUMENTATION
REQUIREMENTS.

To Call:

GE - 5-8111 (ext 5)

DC - 9-1-301-2-751

WU - 815-942-4142

Stephen J. Intended
Dresden Nuclear Power Station
Westinghouse Electric Company
B.