

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME: 01 I L D R S 3 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

CATEGORY: 01 CONT 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

EVENT DESCRIPTION

02 DURING QUARTERLY MSIV TIMING SURVEILLANCE TESTING, MSIV 3-203-1A CLOSED IN 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

03 5.5 SECONDS (UPPER TECH SPEC LIMIT: 5.0 SECONDS). REDUNDANT MSIV 3-203-2A WOULD 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

04 HAVE EFFECTIVELY ISOLATED "A" MAIN STEAM LINE WITHIN 5.0 SECONDS HAD ISOLATION 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

05 BEEN REQUIRED. ABOVE-LIMIT CLOSURE TIMES FOR MSIV'S HAVE BEEN OBSERVED INFREQUENTLY 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

06 IN THE PAST, THIS EVENT WAS NOT REPORTED PROMPTLY BECAUSE THE INITIAL REPORT DOCUMENT WAS MISLAID. 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

(50-249/1976-12)

SYSTEM CODE: 07 C D 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

CAUSE DESCRIPTION

08 DURING THE FOUR-DAY UNIT OUTAGE IMMEDIATELY PRIOR TO TESTING, THE VALVE PACKING APPARENTLY DRIED 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

09 SLIGHTLY, RESULTING IN A SLIGHTLY INCREASED CLOSURE TIME. THE VALVE TIMING WAS ADJUSTED 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

10 AND THE VALVE WAS CLOSED THREE TIMES WITHIN TECH SPEC TIME LIMITS. ADJUSTMENT 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

(CONTINUED BELOW)

11 FACILITY STATUS: G % POWER: 0 0 0 OTHER STATUS: NA METHOD OF DISCOVERY: B DISCOVERY DESCRIPTION: NA 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

12 FORM OF ACTIVITY RELEASED: Z CONTENT OF RELEASE: Z AMOUNT OF ACTIVITY: NA LOCATION OF RELEASE: NA 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

PERSONNEL EXPOSURES

13 NUMBER: 0 0 0 TYPE: Z DESCRIPTION: NA 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

PERSONNEL INJURIES


14 NUMBER: 0 0 0 DESCRIPTION: NA 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

OFFSITE CONSEQUENCES

15 NA 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

LOSS OR DAMAGE TO FACILITY

16 TYPE: Z DESCRIPTION: NA 7 8 9 10 11 12 13 14 15 16



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

IE FILE COPY

BBS Ltr. #76-566

July 30, 1976



Mr. James G. Keppler, Regional Director
Directorate of Regulatory Operations - Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Enclosed please find Reportable Occurrence report number 50-249/1976-12.
This report is being submitted to your office in accordance with the Dresden
Nuclear Power Station Technical Specifications, Section 6.6.B.

B. B. Stephenson
Station Superintendent
Dresden Nuclear Power Station

BBS:jo

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
File/NRC

COPY SENT REGION *III*

7859