

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1 6

PLEASE PRINT ALL REQUIRED INFORMATION

LICENSEE NAME 01 1 L D R S 3														LICENSE NUMBER 00-000000-00														LICENSE TYPE 41111						EVENT TYPE 03									
CATEGORY 01 CONT														REPORT TYPE L		REPORT SOURCE L		DOCKET NUMBER 050-0249														EVENT DATE 062276						REPORT DATE 072076					

## EVENT DESCRIPTION

02 DURING ROUTINE INSTRUMENT SURVEILLANCE TESTING, SUSTAINED HIGH REACTOR PRESSURE																																																																															
03 SWITCH 3-263-53A WAS FOUND TO ACTUATE 6 PSI ABOVE THE TECH SPEC LIMIT OF LESS THAN OR																																																																															
04 EQUAL TO 1070 PSI REACTOR VESSEL PRESSURE. PS 3-263-53A WAS IMMEDIATELY RESET TO																																																																															
05 TRIP AT THE CORRECT SETPOINT. REDUNDANT PRESSURE SWITCHES IN THE 263-53 INSTRUMENT																																																																															
06 GROUP WERE AVAILABLE AND OPERABLE. THIS IS A REPETITIVE EVENT. (50-249/1976-11)																																																																															

SYSTEM CODE 07 S F				CAUSE CODE E		COMPONENT CODE I N S T R U												PRIME COMPONENT SUPPLIER N		COMPONENT MANUFACTURER M 2 2 5						VIOLATION Y	
-----------------------	--	--	--	-----------------	--	-------------------------------	--	--	--	--	--	--	--	--	--	--	--	-------------------------------	--	-----------------------------------	--	--	--	--	--	----------------	--

## CAUSE DESCRIPTION

08 THE EVENT WAS CAUSED BY INSTRUMENT SETPOINT DRIFT. PS 3-263-53A WILL BE CHECKED ON A																																																																															
09 MONTHLY BASIS UNTIL IT CONSISTENTLY EXHIBITS WHAT THE STATION CONSIDERS TO BE ACCEPTABLY																																																																															
10 CONSERVATIVE DRIFT. THE INSTRUMENT IS A MELETRON MODEL #372 BOURDON TUBE-TYPE PRESSURE SWITCH.																																																																															

FACILITY STATUS 11 E		% POWER 073		OTHER STATUS NA		METHOD OF DISCOVERY B		DISCOVERY DESCRIPTION NA	
FORM OF ACTIVITY RELEASED 12 Z		CONTENT OF RELEASE Z		AMOUNT OF ACTIVITY NA		LOCATION OF RELEASE NA			

## PERSONNEL EXPOSURES

NUMBER 13 000		TYPE Z		DESCRIPTION NA	
------------------	--	-----------	--	-------------------	--

## PERSONNEL INJURIES

NUMBER 14 000		DESCRIPTION NA	
------------------	--	-------------------	--

## OFFSITE CONSEQUENCES

15 NA																																																																															
-------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

## LOSS OR DAMAGE TO FACILITY

TYPE 16 Z		DESCRIPTION NA	
--------------	--	-------------------	--

## PUBLICITY

17 NA		8306130039 760720 PDR ADOCK 05000249 S PDR	
-------	--	--	--

## ADDITIONAL FACTORS

18 NA																																																																															
-------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

19																																																																															
----	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

NAME: EDWARD L. SECKINGER

PHONE: EXT. 421



Commonwealth Edison  
Dresden Nuclear Power Station  
R.R. #1  
Morris, Illinois 60450  
Telephone 815/942-2920

IE FILE COPY

BBS Ltr. #76-549

July 20, 1976



Mr. James G. Keppler, Regional Director  
Directorate of Regulatory Operations - Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Enclosed please find Reportable Occurrence report number 50-249/1976-11.  
This report is being submitted to your office in accordance with the Dresden  
Nuclear Power Station Technical Specifications, Section 6.6.B.

B. B. Stephenson  
Station Superintendent  
Dresden Nuclear Power Station

BBS:jo

Enclosure

cc: Director of Inspection & Enforcement  
Director of Management Information & Program Control  
File/NRC

COPY SENT REGION  
COPY SENT REGION