

MGMWSHT HSB  
2-034382E074 03/15/74  
ICS IPMBNGZ CSP  
3096542241 MGM TDBN CORDOVA IL 100 03-15 0549P EDT  
ZIP 20545

western union

Mailgram



JOHN F O'LEARY, DIRECTORATE OF LICENSING  
U.S. ATOMIC ENERGY COMMISSION  
WASHINGTON DC 20545

50-265

REFERENCE QUAD CITY'S NUCLEAR POWER STATION LICENSE DPR-30 DOCKET  
50265 APPENDIX A SECTIONS 1.0.A.2 AND 3.7.A.5.A AND 6.6.B AT  
ABOUT 1200 ON MARCH 15 1974 THE UNIT 2 DRYWELL OXYGEN CONCENTRATION  
WAS DETERMINED TO BE 5.5 PERCENT WHICH IS SLIGHTLY IN EXCESS  
OF THE 5 PERCENT ALLOWED BY TECHNICAL SPECIFICATION 3.7.A.5.A  
THE NITROGEN REGULATOR BYPASS VALVE WAS OPENED TO LET IN MORE  
NITROGEN TO PRIMARY CONTAINMENT NITROGEN TANK INVENTORY IS FULL  
AND THE OXYGEN CONCENTRATION WAS BROUGHT TO 5 PERCENT AT 4:30PM  
N J KALIVIANAKIS

17:49 EST

MGMWSHT HSB



8306130092 740321  
PDR ADDCK 05000265  
S PDR

*Handwritten signature and date 3-26-74*

COPY SENT REGION III

2223