



Telegram

VEA201(1603)(2-030479E052)PD 02/21/74 1603

194 FEB 21 PM 3:13

ICS IPMBNGZ CSP

3096542241 TDBN CARDOVA IL 107 02-21 0403P EDT

PMS J KEPPLER DIRECTORATE OF REGULATORY OPERATION ATOMIC ENERGY  
COMMISSION, DLR

00493

799 ROOSEVELT RD

GLEN ELLYN IL 60017

REFERENCE QUAD CITIES NUCLEAR POWER STATION DOCKET 50-254 DPR29

APPENDIX A SECTIONS 1.0.8.2 AND 3.7.A.1.B AND 6.6.B AT ABOUT

0115 ON FEBRUARY 21ST THE UNIT ONE SUPPRESSION CHAMBER WATER

LEVEL INCREASED TO APPROXIMATELY PLUS 2 AND 1 FOURTH INCHES

EXCEEDING THE REQUIREMENTS OF PLUS TWO INCHES SPECIFIED IN 3.7.A.1.B

THE LEVEL INCREASE RESULTED FROM LEAKAGE ON 1-1001-42A VALVES

WHEN VALVES 1-1001-41 AND 1-1001-42 WERE OPEN TO FILL UNIT ONE

SPENT FUEL POOL FROM THE CONTAMINATED CONDENSATE STORAGE TANK

USING IC AND LETTERS RHR PUMP VALVE 1-1001-42A WAS TIGHTEN AND

SF-1201 (R5-69)

8306130140 740301  
PDR ADOCK 05000254  
S PDR

western union

Telegram

EXCESS WATER WAS PUMPED FROM THE SUPPRESSION CHAMBER TO THE  
UNIT ONE HOT WELL


N KALIVIANAKINS

NNNN

TELEGRAMS (OTHER THAN MONEY ORDERS)  
Is PHYSICAL DELIVERY requested? (YES-AGENT, NO-ADDRESSEE)  
AGENT SELECTION  
NB: & Nbr  
Date dtd 2-21 Time 3:13  
To be sent by first class  
Attempts to deliver (indicate DA or BY)  
312-858-2660  
4381 To Pdc By dc  
maul

FEB 25 1974

SF-1201 (R5-69)



UNITED STATES  
ATOMIC ENERGY COMMISSION  
DIRECTORATE OF REGULATORY OPERATIONS  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TELEPHONE  
(312) 858-2660

A. RO Inspection Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:  
RO Chief, FS&EB  
RO:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
RO Files

Distribution:  
RO Chief, FS&EB  
RO:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
RO Files

B. RO Inquiry Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:  
RO Chief, FS&EB  
RO:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
RO Files

Distribution:  
RO Chief, FS&EB  
RO:HQ  
DR Central Files  
RO Files

C. Incident Notification From: Commonwealth Edison Co. Docket No. 50-254  
(Licensee & Docket No. (or License No.))

Transmittal Date : March 13, 1974

Distribution:  
RO Chief, FS&EB  
RO:HQ (4)  
Licensing (4)  
DR Central Files  
RO Files

Distribution:  
RO Chief, FS&EB  
RO:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
RO Files

50-254  
incident