

NNNN

WU AGCY WHEA

W7 QTU DL

WU 157 DL

522P CST

EC253 1744) 2-077986E313)PD 11/09/73 1744

ICS IPMBNGZ CSP

3096542241 TDBN CORDOVA IL 93 11-09 0544P EST

PMS J KEPPLER, DLR

DIRECTORATE OF REGULATORY OPERATION REGION 3 U S ATOMIC ENERGY

COMMISSION 799 ROOSEVELT RD

GLEN ELLYN IL 60137

REFERENCE QUAD CITY NUCLEAR POWER STATION DOCKET NUMBER 50-254
DPR29 APPENDIX A 10A2 AND 32A AND 66B DURING A ROUTINE CALIBRATION
OF THE PRESSURE SWITCHES WHICH MONITOR FLOW IN THE MAIN STEAMLINE
THE SET POINTS OF 3 SWITCHES WERE FOUND TO EXCEED THE LIMITING
CONDITION FOR OPERATION OF TABLE 321 OF THE TECHNICAL SPECIFICATIONS.

DPIS-261-2G TRIPPED AT 110 PSID AND SWITCHES 2J AND 2M TRIPPED
AT 109.5 PSID. THE EQUIVALENT OF 120 PERCENT FLOW IS 109 PSID.
THE 2G 2J AND 2M SWITCHES WERE RECALIBRATED TO 105.5, 105.5,
AND 106.5 PSID RESPECTIVELY.

1973 NOV 9 PM 5 33

N J KALIVIANAKIS ASSISTANT SUPERINTENDENT

NNNN

8306130250 731119

PDR ADOCK 05000254

S

PDR

0;

WU AGCY WHEA NOV 12 1973

0