



western union

Telegram

VEE148(1312)(2-153336E269)PD 09/26/73 1309
ICS IPMBNGZ CSP
3096542241 TDBN CORDOVA IL 101 09-26 0109P EST

PMS J KEPPLER DIRECTOR OF REGULATORY OPERATION, FONE
IS ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD
ILEN ELLYN IL 60137

REFERENCE QUAD CITY NUCLEAR POWER STATION DOCKETT NUMBERS 50-254
AND 50-265 DPR 29 AND 30 APPENDIX A SECTIONS 1.0.A.2 AND 3.8.B.3.A
AND 6.6.B AT 1500 ON 9-25-73 IT WAS DETERMINED FROM THE 48 COUNT
OF LONGLIVED PARTICULATES THAT THE RELEASE RATE FROM THE REACTOR
BUILDING VENT STACK WAS ABOUT 120 PERCENT OF THE TECHNICAL SPECIFICAT
IONS LIMIT 3.8.B.3.A ON 9-22-73 ANALYSIS OF THE 9-23-73 PARTICULATE
SAMPLES REVEALED THE RELEASE ON THAT DAY WAS 71 PERCENT OF THE
LIMIT THE VENT SYSTEM WAS ISOLATED FOR A PERIOD OF ABOUT 6 HOURS
EACH DAY

SEP 28 1973

B B STEVENSON SUPERINTENDENT

8306140138 731115
PDR ADDCK 05000254
PDR

Nbr. & Name

09-26

Nbr

Q12-358-2660

To be mailed or filed

445P

1973 SEP 26 PM 1:14

Attempts to deliver (indicate DA or BY)

mail



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

TELEPHONE
(312) 858-2660

A. RO Inspection Report No. _____

Transmittal Date : _____

Distribution:
RO Chief, FS&EB
RO:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)

Distribution:
RO Chief, FS&EB
RO:HQ (4)
L:D/D for Fuel & Materials
DR Central Files

B. RO Inquiry Report No. _____

Transmittal Date : _____

Distribution:
RO Chief, FS&EB
RO:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)

Distribution:
RO Chief, FS&EB
RO:HQ
DR Central Files

C. Incident Notification From: Commonwealth Edison 50-254/50-265
(Licensee & Docket No. (or License No.))

Transmittal Date : September 28, 1973

Distribution:
RO Chief, FS&EB
RO:HQ (4)
Licensing (4)
DR Central Files
RO Files

Distribution:
RO Chief, FS&EB
RO:HQ (4)
L:D/D for Fuel & Materials
DR Central Files

Handwritten:
50-254/265