

MSMCGBE CGO
2-207645E222 08/10/73
ICS IPMBNGZ CSP
3090600000 MGM TDBN CORDOVA IL 155 08-10 0219P EST
ZIP 60137

western union

Mailgram



B H GRIER REGION 3
COMPLIANCE US ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD
GLEN ELLYN IL 60137

REFERENCE QUAD CITIES NUCLEAR POWER STATION UNIT 1 DOCKET #50-254
DPR 29 APPENDIX A SECTION 1.0.A.2 AND 3.7.A.1.B AND ABOUT 0630
AUGUST 10 THE UNIT 1 SUPPRESSION CHAMBER WATER LEVEL INCREASED
TO 24 INCHES THUS EXCEEDING THE REQUIREMENTS OF SPECIFICATION
3.7.A.1.B THE REACTOR WAS SHUT DOWN WITH PRESSURE LESS THAN
50 PSIG AT THE TIME A COOL DOWN WAS IN PROGRESS FOR A DRYWELL
ENTRY TO INSPECT MSVIID WHICH HAD CLOSED AT 0020 CAUSING A FULL
ISOLATION AND SCRAM AT 0625 RHR SYSTEM WAS BEING LINED UP FOR
SHUT DOWN COOLING AND DUE TO IMPROPER VALVE LINEUP WATER WAS
TRANSFERRED FROM THE CONDENSATE STORAGE TANK TO THE TORUS AND
0635 SHUT DOWN COOLING WAS ESTABLISHED AND VESSEL DEPRESSURIZATION
CONTINUED REACTOR PRESSURE WAS REDUCED TO ZERO AT ABOUT 0800
N KALIVIANAKIS COMMONWEALTH MEDICINE CO BOX 216 CORDOVA IL
61242

1423 EST

MGMCGBE CGO

8306140307 730820
PDR ADOCK 05000254
S PDR

U.S. ATOMIC ENERGY COMM.
DIVISION OF COMPLIANCE

1973 AUG 17 AM 12 12

RECEIVED

AUG 16 1973