


MGMCGBA CGO
2-085791E219 08/07/73
ICS IPMBNGZ CSP
3096542241 MGM TDBN CARDOVA IL 229 08-07 0508P EST
ZIP 60137



Mailgram

Q

B H GRIER
REGION 3 COMPLIANCE US ATOMIC ENERGY COMMISSION 799 ROSEVELT
RD
GLENELLEN IL 60137

REFERENCE QUAD CITIES NUCLEAR POWER STATION UNITS ONE AND TWO
DOCKET NUMBERS 50-254 AND 265 DPR29 AND 30 APPENDIX A SECTION
3.8.B.3 AND 1.0.A.2 DPR 29 APPENDIX A SECTION 3.7.A.5 AND 1.0.A.2
THIS IS TO REPORT TWO ABNORMAL ACCURANCES AT QUAD CITIES NUCLEAR
POWER STATION 1. SUBSEQUENT TO A REACTOR START UP ON AUGUST
6 ON UNIT ONE THE PRIMARY CONTAINMENT WAS NOT INERTED WITHIN
24 HOURS AS REQUIRED BY TECHNICAL SPECIFICATION 3.7.A.5 THE
ONSIGHT NITROGEN STORAGE TANK WAS DEPLETED BY INERTING UNIT
TWO THE DAY BEFORE AND A TRUCK WAS SCHEDULED IN OR INERTING
UNIT ONE AT 2200 AUGUST 6 THE TRUCK DID NOT ARRIVE UNTIL 0500
AUGUST 7 THE 24 HOUR PERIOD EXPIRED ABOUT 0230 INERTING IS NOW
IN PROGRESS 2. ABOUT 0230 AUGUST 7 THE REACTOR BUILDING DEN
SIACK SAMPLE CARTRIDGE WAS ANALYSED AND IT WAS DETERMINED
THAT THE RELEASE RATE LCO FOR IODINE 131 WAS EXCEEDED BY ABOUT
20 PERCENT ON AUGUST 6 THE VENT SYSTEM WAS ISOLATED AND HE STAND
BY GAS SYSTEM INITIATED AT THAT TIME OUR SUBSEQUENT INSPECTION
FOR LEAKS FOUND ONLY ONE VALVE IN THE UNIT ONE CLEAN UP HEAT
EXCHANGER ROOM WHICH WAS BLOWING BY THIS HAS BEEN CORRECTED
AND THE VENT SYSTEM IS BEING RETURNED TO NORMAL FOR AN 8 HOUR
PERIOD WITHIN INCREASED SURVALLANCE

N KALIVIANAKIS

1710 EST


MGMCGBA CGO

8306140815 730817
PDR ADOCK 05000254
S PDR

RECEIVED
AUG 12 1973

AUG 8 1973

Handwritten signature and date: 50-254/265



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

TELEPHONE
(312) 858-2660

A. RO Inspection Report No. _____

Transmittal Date : _____

Distribution:
RO Chief, FS&EB
RO:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)

Distribution:
RO Chief, FS&EB
RO:HQ (4)
L:D/D for Fuel & Materials
DR Central Files

B. RO Inquiry Report No. _____

Transmittal Date : _____

Distribution:
RO Chief, FS&EB
RO:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)

Distribution:
RO Chief, FS&EB
RO:HQ
DR Central Files

C. Incident Notification From: Commonwealth Edison Co. 50-254 and 50-265
(Licensee & Docket No. (or License No.))

Transmittal Date : August 9, 1973

Distribution:
RO Chief, FS&EB
RO:HQ (4)
Licensing (4)
DR Central Files
RO Files

Distribution:
RO Chief, FS&EB
RO:HQ (4)
L:D/D for Fuel & Materials
DR Central Files