

James G. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

REC'D 3-11-75 2:30
Teletyped Date 3-11-75
DE
Telegraphed: GE 2:20 pm
DC
By aw

cc:

J. F. O'Leary, Director
Directorate of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: DPR-15, Dresden Nuclear Power Station, Unit 3.

This will confirm a conversation with Mr. P. JOHNSON of
your office at 4:00 hrs this date concerning FAILURE OF ECCS
LOW PRESSURE INITIATING SWITCH PS3-263-52A-1
TO TRIP WITHIN THE TECHNICAL SPECIFICATION LIMITS. THIS
WAS APPARENTLY THE RESULT OF THE INSTRUMENT SETPOINT
DRIFT. SWITCH WAS IMMEDIATELY RESET TO CORRECT
SETPOINT. OTHER SWITCHES WERE SATISFACTORILY REED
AT THIS TIME.

8306150147 750311
PDR ADOCK 05000249
S PDR

To Call:

GE - 5-858-2660x16 (auto)
DC - 9-1-391-492-7617 (auto) - on 6
WB - 815-942-4449/4321

Station Dist: Originator (copy)
Incident File (copy)
Telegram File (original)

B. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450

Telephone: 815-942-2920/2921x212
(telecopy x262)

50-237

Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Teletype or
Teletype
Date
CE 11:05
DC 11:15
By AM

cc:
Bernard C. Rusche, Director
Directorate of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

50-249

SUBJECT: DPR- 19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with MR JOHNSON of
your office at 0955 hrs this date concerning FAILURE OF DRYWELL
EQUIPMENT SUMP PUMP DISCHARGE VALVE RD-2-2001-5 TO
CLOSE DURING QUARTERLY VALVE TIMING TESTS 13 MAY 1975.
Reactor was in Cold Shutdown Condition at this time and
Reactor Containment was not Pressured. Other Valve in Line
was demonstrated operable. The Valve will be Retained Prior
to Start-Up

50-249

NO DATE

NOT CODEABLE