

TWX INCOMING

BETH 206

50-249

USAEC-WIS-STW

1975 FEB 20 AM 8 22

INFO ASTER 1-0434940050 02/10/75

TLX TO TFC WSA

0100

TLX 7100000475 USAEC-WIS-STW

U.S. ATOMIC ENERGY COMM.
TWX UNIT



CP2100 MAL154(1755)(3-0373120050)PD 02/10/77 1755

100 IP 100Z CSP

1100414445 TBSN MORRIS IL 71 02-10 0555P EST

P. S. J. F. DIRECTOR, DIRECTORATE OF LICENSING, U.S. ATOMIC

COMMISSION, WASHINGTON DC 20545

SUBJECT: SPR-25, BRIDGES NUCLEAR POWER STATION UNIT 3.

THIS WILL CONFIRM A CONVERSATION WITH PAUL JOHNSON OF YOUR OFFICE AT 1000 HOURS THIS DATE CONCERNING REACTOR VESSEL LOW WATER LEVEL FORAM AND LOW LOW ISOLATION SWITCH L108-363-372 TO TRIP WITHIN THE TECHNICAL SPECIFICATION LIMITS. THIS WAS APPARENTLY THE RESULT OF AN INSUFFICIENT SHIPMENT. INVESTIGATION IS IN PROGRESS. THE SWITCH WAS IMMEDIATELY RESTORED TO CORRECT SETTINGS. OTHER SWITCHES WERE SATISFACTORILY TESTED AT THIS TIME.

J. STEPHENSON SUPERINTENDENT BRIDGES NUCLEAR POWER STATION

COMMONWEALTH EDISON COMPANY ROUTE 1 MORRIS IL 60450

1055 EST

USAEC-WIS-TW

1384

TWX INCOMING

50-249
incident

8306150231 750227
PDR ADCK 05000249
S PDR

COPY SENT REGION