

western union

Telegram

VEA233(1753)(2-037156E050)PD 02/19/75 1753

ICS IPMBNGZ CSP

8159424449 TDBN MORRIS IL 78 02-19 0553P EST

PMS JAMES G KEPPLER, REGIONAL DIRECTOR, DIRECTORATE OF REGULATORY
OPERATIONS-REGION 3, U.S. ATOMIC COMMISSION, WUX

799 ROOSEVELT RD

GLEN ELLYN IL 60137

SUBJECT: DPR-25, DRESDEN NUCLEAR POWER STATION UNIT 3.

THIS WILL CONFIRM A CONVERSATION WITH PHIL JOHNSON OF YOUR OFFICE AT
1600 HOURS THIS DATE CONCERNING REACTOR VESSEL LOW WATER LEVEL SCRAM
AND LOW LOW ISOLATION SWITCH LIS3-263-57B TO TRIP WITHIN THE
TECHNICAL SPECIFICATION LIMITS. THIS WAS APPARENTLY THE RESULT OF AN
INSTRUMENT SET POINT DRIFT AND INVESTIGATION IS IN PROGRESS. THE
SWITCH WAS IMMEDIATELY RESTORED TO CORRECT SETTING. OTHER SWITCHES
WERE SATISFACTORILY TESTED AT THIS TIME.

B B STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON COMPANY ROUTE 1 MORRIS IL 60450
NNNN

8306150252 750218
PDR ADDCK 05000249
PDR

-1201 (R5-69)

SF-1201 (R5-69)

FEB 24 1975

1975 FEB 19 PM 4:56

312-858-2660

PHJ BY 89

2/20 TIME 104017

mail