

RE 00 12/3/74 8:55 2

TO:
James G. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U.S. Atomic Energy Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DATE 2/1/80
Telecopied: Date 2 Dec 74
CZ 0835 2/1/74
DC 1540 2/1/74
By RLB

CC:
J. F. O'Leary, Director
Directorate of Licensing
U.S. Atomic Energy Commission
Washington, D.C. 20545

SUBJECT: DPR-25, Dresden Nuclear Power Station, Unit 3

This will confirm a conversation with C. Feierabend of
your office at 1400 hrs this date concerning
the discovery, while the unit was shut down, of
minor leaks on the minimum flow lines for 3A
and 3B reactor feed pumps. The leakage was
very minor in nature & wholly contained within
the turbine building floor drain system.

8306150553 741206
PDR ADDCK 05000249
S PDR

Station Dist: Originator (copy)
Incident File (copy)
Telegram File (original)

To Call:

CZ - 5-855-2669x16

DC - 5-1-301 2617 (auto)

67-249
inquiry

RECEIVED
1974 DEC 10 AM 10 44
U.S. ATOMIC ENERGY COMM
DIVISION OF COMPLIANCE

B. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
E.E. #1
Morris, IL 60450
Telephone: 815-942-2970/2921x212