



Telegram

Date dtd 7/16 2374 to J.K. by 75  
To be mailed or filed *mail* 1974 JUL 16 PM 3:12

VEE220116089 (P-0343800107) 87 PRG 74 1004

ICS IPMVEIC-PVY

03103 TDVE MORRIS ILL 111 07-16 100P CDT  
RMS MR JAMES G KEPPLER REGIONAL DIRECTOR  
DIRECTORATE OF REGULATORY OPERATIONS REGION 3  
WUX US ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD  
GLEN ELLYN ILL 60137

SUBJECT DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3.  
THIS WILL CONFIRM A CONVERSATION WITH F MAURA OF YOUR OFFICE  
AT 10.30 HRS THIS DATE CONCERNING THE FAILURE TO REACH THE  
REQUIRED CONTAINMENT OXYGEN CONCENTRATION OF 4-0% WITHIN 24 HRS  
OF PLACING THE MODE SWITCH IN THE RUN POSITION AS REQUIRED BY  
SPECIFICATION 3.7.A.5.8 OF THE TECHNICAL SPECIFICATION AT 9.35 AM  
ON THIS DATE WHEN THE TWENTY FOUR HOURS EXPIRED CONTAINMENT  
OXYGEN CONCENTRATION AVERAGED 4.5 PERCENT. IN INVERTING IS  
CONTINUING AND THE CONCENTRATION SHOULD BE WITHIN SPEC SHORTLY.

SF-1201 (RS-89)

ADDITIONAL DETAILS WILL BE FORTHCOMING IN THE FORM OF A TEN  
DAY LETTER

R B STEPHENSON, SUPERINTENDENT  
DRESDEN NUCLEAR POWER STATION  
COMMONWEALTH EDISON COMPANY  
RR #1 MORRIS ILLINOIS 60450

NNNN

JUL 18 1974

8306150613 740722  
PDR ADOCK 05000249  
S PDR

*Handwritten signature and date 7/24/74*