

MGMCGBA CGO
2-028798E277 10/04/74
ICS IPMBNGZ CSP
8159422920 MGM TDBN MORRIS IL 135 10-04 0314P EDT
ZIP 60137



western union

Mailgram



THIS MAILGRAM WAS TRANSMITTED ELECTRONICALLY BY WESTERN UNION TO A POST OFFICE NEAR YOU FOR DELIVERY

► JAMES G KEPPLER REGIONAL DIRECTOR DIRECTORATE OF REGULATORY OPERATION
REGION 3 US ATOMIC ENERGY COMMISSION
799 ROOSEVELT RD
GLEN ELLYN IL 60137

DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3 THIS WILL CONFIRM A
CONVERSATION WITH F MAURA OF YOUR OFFICE AT 1320 HOURS THIS DATE
CONCERNING THE DISCOVERY DURING ROUTINE CALIBRATION OF DPIS3-2352
WITH A SET POINT OF 155 INCHES OF WATER WHICH IS GREATER THAN THE
150 INCHES OF WATER ALLOWED BY TABLE 3.2.1 OF THE TECHNICAL SPECIFICATIO
NS THIS SWITCH WHICH IS ONE OF THE TWO WHICH ISOLATE THE HPCI SYSTEM
ON HIGH STEAM FLOW WAS IMMEDIAELY RESET TO WITHIN SPECIFICATIONS
THE OTHER HIGHS STEAM FLOW SWITCH DPIS3-2351 WAS TESTED AND FOUND
TO BE WITHIN SPECIFICATIONS

B B STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION COMMONWEAL
TH EDISON CO RR 1 MORRIS IL 60450

1518 EDT

MGMCGBA CGO

OCT

7 1974

8306150640 741009
PDR ADOCK 05000249
S PDR