

TO:
Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DATE: 3-22-77

Telecopies Date _____
or
Telegrammed GE 3-23-77

DC _____

By BC

cc:

~~Director
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555~~

50-249

SUBJECT: DPE-25, Dresden Nuclear Power Station, Unit 3.

This will confirm a conversation with Mr. F. Maura of
your office at 1540 ^{3/22/77} hrs ~~this date~~ concerning simultaneous inoperability
of the Unit 3 and 2/3 diesel generators with the Unit in
power operation at 800 Mw. The Unit 3 diesel started but
the field failed to flash at 0200, 3/22/77, while completing
operability surveillance following maintenance on system
air compressors. Twenty-eight minutes (28) later, while
completing operability tests for the failed Unit 3 diesel, the
2/3 diesel did not start on the first attempt at starting.
Subsequent starts at 0245 and 0325 proved successful.
Since no problems could be found, the 2/3 diesel was
considered operational at this point. However, it is assumed
that the diesel was unavailable between the time Unit 3
diesel failed to load and the demonstrated operability
on subsequent tests.

8306160051 770411
PDR ADOCK 05000249
S PDR

To Call:
GE - 7-858-2650x16
DC - 9-1-301-492-7617 (auto)
NU - 815-942-4449/4321

Station Dist: Originator (copy)
Incident File (copy)

E. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450

Telephone: 815-942-2920/2921x212

Rev. 12-75

REC'D 9/16 3/23/77

TO:
Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DATE: 12/15/76 *IE*
Telecopies Date 12-15-76 *Files*
or
Telegraphed GE 1:34 pm.
DC _____
By BB

cc:
~~Director~~
~~Office of Management Information and Program Control~~
~~U.S. Nuclear Regulatory Commission~~
~~Washington, DC 20555~~

50-237
50-249

SUBJECT: DPR-19425 Dresden Nuclear Power Station, Unit 2 & 3

This will confirm a conversation with W. Schaeffer of
your office at 12:50 hrs this date concerning 440 reduction
in allowable MAPLNGR resulting from
an error in S.E. ECCS analysis.
Heat started by reactor ceased and
components was inadvertently doubled.

J.S. Kolanowski

Dupe 8304050094

To Call:
GE - 7-858-2660x16
DC - 9-1-301-492-7617 (auto)
WU - 815-942-4449/4321

Station Dist: Originator (copy)
Incident File (copy)
Telegram File (orig)

F. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450

Telephone: 815-942-2920/2921x212
(telecopy x262)

Rev. 12-75

Received 1:50 12/15/76