

MGMCGBA CGO
2-037185E273 09/30/74
ICS IPMSNGZ CSP
8159422920 MGM TDBN MORRIS IL 100 09-30 0522P EDT
ZIP 60137

western union Mailgram



JAMES G KEPPLER REGIONAL DIRECTOR
DIRECTORATE OF REGULATORY OPERATIONS REGION 3 US ATOMIC ENERGY COMMISSIO
N 799 ROOSEVELT RD
GLEN ELLYN IL 60137

DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3 THIS WILL CONFIRM A
CONVERSATION WITH C BROWN OF YOUR OFFICE AT 1600 HOURS THIS DATE
CONCERNING A DISCOVERY OF LITS 3-263-72A AND THE SET POINTS WHICH
EXCEEDED THE LIMITING SETTINGS ALLOWED BY THE TECHNICAL SPECIFICATIONS.
THE SET POINTS WERE DISCOVERED TO BE APPROXIMATELY ONE TO TWO
INCHES GREATER THAN THE 257 INCHES OF WATER DIFFERENTIAL PRESSURE
PERMISSIBLE.

B B STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION COMMONWEAL
TH EDISON COMPANY RR 1 MORRIS IL 60450

1727 EDT

MGMCGBA CGO

8306160063 741008
PDR ADOCK 05000249
S PDR

OCT 1 1974