

OV  
WU AGCY WHEA  
WU MVN ILL

1974 SEP 24 PM 3 04

WU VN ILL  
@;  
WU AGCY WHEA  
WUA 178 & 3 304P CDT  
VEC223 1533) 2-027369E267) PD 09/24/74 1533  
ICS IPMBNGZ CSP  
8158422920 TDBN MORRIS IL 69 09-24 0333P EDT  
PMS JAMES G KEPPLER, REGINAL DIRECTOR DIRECTORATE OF REGULATORY  
OPERATIONS-REGION IIIUS ATOMIC ENERGY COMMISSION , DLR  
799 ROOSEVELT RD  
GLEN ELLYN IL 60137  
SUBJECT DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3  
WILL CONFIRM A CONVERSATION WITH F. MAURA OF YOUR OFFICE AT  
11AM THIS DATE CONCERNING A THROUGH WALL CRACK DISCOVERED ON  
TORUS PURGE INLET LINE 3-8506-18". THE CRACK WAS DISCOVERED  
WHILE THE UNIT WAS SHUT DOWN AND LOCAL LEAK RATE TESTING WAS  
IN PROGRESS. INVESTIGATION INTO THE FAILURE MODE AND REPAIR  
PROCEEDURES IS UNDERWAY.  
STEPHENSON SUPERINTENDENT DRESDEN NUCLEAR POWER STATION COMMON  
WEALTH EDISON COMPANY RTE 1 MORRIS ILLINOIS 60450

8306160082 760218  
PDR ADDCK 05000249  
S PDR

SEP 24 1974