



Telegram

VEC161(1451)(1-023164C266)PD 09/23/74 1449

ICS IPMVEIC MVN

03194 TDVE MORRIS IL 56 09-23 1250P CDT

PMS JAMES KEPPLER REGIONAL DIREC DIRECTORATE OF REGULATORY
OPERATIONS-REGION 3 WUX US ATOMIC ENERGY COMMISSION

799 ROOSEVELT RD GLEN ELLYN IL 60137

SUBJECT: DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3.

THIS WILL CONFIRM A CONVERSATION WITH MR. MAURA OF YOUR OFFICE AT
1400 HOURS 9-21-74 CONCERNING A MINOR LEAK FROM FEED WATER PRESSURE
TAP 3241-12A. TO REPAIR THIS LEAK AN ORDERLY SHUT DOWN OF THE RE
ACTOR WAS INITIATED. LEAKAGE PRESENTED NO OPERATIONAL OR
CONTAMINATION PROBLEM

B B STEPHENSON SUPT DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON COMPANY R R 1 MORRIS ILL 60450

1974 SEP 23 PH 1:52

312-858-2660
HDD
307P
mail

NNNN

SEP 26 1974

8306160085 740926
PDR ADDCK 05000249
S PDR

1201 (RS-89)