



Telegram

VEE202(1757)(1-037732C252)PD 09/09/74 1754

1974SEP-9 PM 5:15

ICS IPMVEIC MVN

03324 TDVE MORRIS IL 75 09-9 401P CDT

PMS MR JAMES G KEPPLER REGIONAL DIRECTOR

DIRECTORATE OF REGULATORY OPERATIONS REGION 3

WUX US ATOMIC ENERGY COMMISSION

799 ROOSEVELT RD

GLEN ELLYN IL 60137

SUBJECT DPR-25, DRESDEN NUCLEAR POWER A STATION, UNIT 3

THIS WILL CONFIRM A CONVERSATION WITH MR MAURA OF YOUR OFFICE

AT 1430 HOURS THIS DATE CONCERNING FAILURE OF "E" TIP VALVE TO

CLOSE AT 2040 SEPTEMBER 8TH 1974 AFTER OPERATING TIP MACHINE

OPERATORS WERE ABLE TO TAP VALVE HOUSING AND VALVE CLOSED

SHORTLY THEREAFTER SHEAR VALVE WAS AVAILABLE AS A BACKUP SHOULD

AN ISOLATION THE REQUIRED INVESTIGATION IS IN PROCESS AT THIS

TIME

SF-1201 (R5-49)

B B STEPHENSON SUPERINTENDENT

DRESDEN NUCLEAR POWER STA

COMMONWEALTH EDISON CO

R R I MORRIS IL 60450

NNNN

TELEPHONE NBR. 312-858-2660
TELEPHONED TO 92 BY 100
DATE DLD 9-10-74 907A
ATTEMPTS TO DELIVER Ma

8306160095 740916
PDR ADOCK 05000249
S PDR