



Commonwealth Edison
Quad-Cities Generating Station
Post Office 216
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-75-439

Telecopy: Region III, Attention: Mr. C. Feierabend

August 31, 1975

J. Keppler, Regional Director
Office of Inspection and Enforcement
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 2
Docket No. 50-265, DPR-30
Appendix A, Sections 1.0.A.5, 6.6.B.1.a

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence:

On August 31, 1975, while shutting down the unit, an instability was experienced on the feedwater control system which caused the 3/4 inch drain lines, both upstream and downstream of the low flow feedwater regulating valve, to sever. The "B" normal flow regulation valve went fully open and the resulting reactor high water level turbine trip scrambled the reactor.

There were no radioactive materials released from the site as a result of this occurrence.

This occurrence was discussed by telephone with Mr. Knop of your office on August 31, 1975. Further information will be provided by Abnormal Occurrence Report AO 50-265/75-36 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
Station Superintendent

NJK/RAR/saa

cc: Office of Nuclear Reactor Regulation
G. A. Abrell

8306160097 750831
PDR ADCK 05000265
S PDR