



Commonwealth Edison.
Quad-Cities Generating Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/854-2241

75-438

Copy: Region III, Attention: Mr. C. Feierabend

August 31, 1975

Mr. Keppler, Regional Director
Office of Inspection and Enforcement
Region III
U.S. Nuclear Regulatory Commission
Roosevelt Road
Springfield, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 2
Docket No. 50-265, DPR-30
Appendix A, Sections 1.0.A.4, 3.5.C.1, 3.5.C.3, 6.6.B.1.a

Re: Mr. Keppler:

The purpose of this letter is to provide you with notification of an
Abnormal Occurrence as required by Technical Specification 6.6.B.1.a
within 24 hours of the occurrence.

On August 30, 1975, while testing the operability of the HPCI system
due to a failure of the RCIC system, it was discovered that the HPCI
system was also inoperable. The auxiliary oil pump kept tripping
and the HPCI turbine would not start.

Since the RCIC system was also inoperable, an orderly shutdown of the
reactor was initiated.

This occurrence was discussed by telephone with Mr. Allen of your
office on August 30, 1975. Further information will be provided by
Abnormal Occurrence Report AO 50-265/75-35 which will be submitted
within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

J. Kalivianakis
J. Kalivianakis
Station Superintendent

VRAR/saa

Office of Nuclear Reactor Regulation
G. A. Abrell

8306160105 750909
PDR ADOCK 05000265
S PDR