

NJK-77-71

Telecopy: Region III, Attention: Mr. N. Jackiw

February 17, 1977

J. Keppler, Regional Director
Office of Inspection and Enforcement
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Units 1 and 2
Docket No. 50-254, DPR-29 and 50-265, DPR-30
Appendix A, Sections 3.5.1 and 6.6.B.1.h

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of a Reportable Occurrence as required by Technical Specification 6.6.B.1 within 24 hours of the occurrence.

On February 17, 1977 information received by the station indicated that the maximum average planar linear heat generation rate (MAPLHGR) limit curves given by the Technical Specifications shall be additionally lowered. Previous reductions in MAPLHGR limits were reported by Reportable Occurrence Report RO 50-254/76-38 dated December 15, 1976 and update report dated January 17, 1977.

This composite reduction has resulted from a review of the ECCS analysis performed to comply with 10 CFR 50 Appendix K.

Accordingly, the MAPLHGR curves presently used in the process computer calculations have been lowered effective February 17, 1977.

This occurrence was discussed at Quad-Cities Station with Mr. N. Jackiw of your office on February 17, 1977. Further information will be provided by an update report for Reportable Occurrence Report RO 50-254/76-38 which will be submitted within 14 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
N. J. Kalivianakis
Station Superintendent

cc: G. A. Abrell

rec'd 4:01 2/17/77 AB

8306160212 770217
PDR ADOCK 05000254
S PDR