



Commonwealth Edison
Quad-Cities Nuclear Power Station
22710
Circled
Telephone 312-444-2710

LE Files

50-254

NJK-77-21

Telecopy: Region III, Attention: Mr. N. Jackie

January 18, 1977

J. Keppler, Regional Director
Office of Inspection and Enforcement
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Units 1 and 2
Ticket No. 50-254, DPR-29 and 50-255, DPR-30
Appendix A, Sections 3.5.1 and 6.6.B.1.h.

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of a Reportable Occurrence as required by Technical Specification 6.A.6.1 within 24 hours of the occurrence.

On January 17, 1977 information received by the station indicated that the maximum average planar linear heat generation rate (PLHGR) limit curves given by the Technical Specifications shall be lowered by an additional 2 percent, based on the original percent reduction previously reported on December 28, 1976 by Reportable Occurrence Report RO 50-254/76-38.

This composite 6 percent reduction has resulted from a review of the ECCS analysis performed to comply with 10 CFR 50 Appendix R.

Accordingly, the PLHGR curves presently used in the process computer calculations have been lowered an additional 2 percent effective January 17, 1977.

This occurrence was discussed by telephonic with Mr. N. Jackie of your office on January 17, 1977. Further information will be provided by an update report for Reportable Occurrence Report RO 50-254/76-38 which will be submitted within 14 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N.J. Kallivayannis
Station Superintendent

NJK/LFG/cb

8306160219 770217
PDR ADOCK 05000254
S PDR

rec'd 12:45 1/18 drc
J.A. Abrell