



Commonwealth Edison  
Quad-Cities Nuclear Power Station  
Post Office Box 216  
Cordova, Illinois 61242  
Telephone 309/654-2241

NJK-75-415

Telecopy: Region III, Attention: Mr. C. Feierabend

August 13, 1975

J. Keppler, Regional Director  
Office of Inspection and Enforcement  
Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station  
Docket No. 50-265, DPR-30  
Appendix A, Section 1.0.A.4, 3.2.B, 6.6.B.1.a


The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

On August 12, 1975, while performing routine surveillance testing of the ECCS low pressure permissive sensors, PS-2-263-52A was discovered in the isolated condition. The other three sensors were not isolated. PS-2-263-52A was put into service and all four switches were satisfactorily functionally tested.

This occurrence was discussed by telephone with Mr. Tambling of your office on August 12, 1975. Further information will be provided by Abnormal Occurrence Report AO 50-265/75-30 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY  
QUAD-CITIES NUCLEAR POWER STATION

  
N. J. Kalivianakis  
Station Superintendent

NJK/RAR/lk

cc: Office of Nuclear Reactor Regulation  
G. A. Abrell

8306160260 750813  
PDR ADOCK 05000265  
S PDR

*Rec'd*  
10:31 AM  
8/13/75



Commonwealth Edison  
Quad-Cities Nuclear Power Station  
Post Office Box 218  
Cordova, Illinois 61242  
Telephone 309/654-2241

NJK-75-422

Telecopy: Region III, Attention: Mr. C. Feierabend

August 18, 1975

J. Keppler, Regional Director  
Office of Inspection and Enforcement  
Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 2  
Docket No. 50-265, DPR-30  
Appendix A, Sections 1.0.A.5, 6.6.B.1.a.

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

On August 17, 1975 while bringing Unit Two back to power following a maintenance outage, the 6" to 4" reducer on the downstream side of low flow feedwater regulating valve, 2-643, severed due to vibration incurred while transferring from the low flow feedwater regulating valve to the main feedwater regulating valve.

The unit was manually scrammed and the reactor level was maintained with the RCIC system. Although contaminated water was introduced into the oil separator none was released to the environs.

This occurrence was discussed by telephone with Mr. Knop of your office on August 17, 1975. Further information will be provided by Abnormal Occurrence Report A0 50-265/75-31 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY  
QUAD-CITIES NUCLEAR POWER STATION

*N. J. Kalivianakis*  
N. J. Kalivianakis  
Station Superintendent

NJK/IK

cc: Office of Nuclear Reactor Regulation  
G. A. Abrell

Dupe of 8306160205

Rec'd 4/21 5/18/75

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

A. IE Inspection Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:  
IE Chief, FS&EB  
IE:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
IE Files

Distribution:  
IE Chief, FS&EB  
IE:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
IE Files  
IE Chief, M&PPB  
L:D/D for Reactor Project

B. IE Inquiry Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:  
IE Chief, FS&EB  
IE:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
IE Files

Distribution:  
IE Chief, FS&EB  
IE:HQ  
DR Central Files  
IE Files

C. Incident Notification From: Commonwealth Edison Company 50-254  
(Licensee & Docket No. (or License No.))

Transmittal Date : Quad-Cities Unit 1 August 21, 1975

Distribution:  
IE Chief, FS&EB  
IE:HQ (4)  
Licensing (4)  
DR Central Files  
IE Files

Distribution:  
IE Chief, FS&EB  
IE:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
IE Files

