



Commonwealth Edison  
Quad-Cities Generating Station  
Post Office Box 216  
Cordova, Illinois 61242  
Telephone 309/654-2241



NJK-75-386

TELECOPY: Region III, ATTENTION: Mr. C. Feierabend  
July 30, 1975

J. Keppler, Regional Director  
Directorate of Regulatory Operations  
Region III  
U. S. NUCLEAR REGULATORY COMMISSION  
799 Roosevelt Road  
Glen Ellyn, IL 60137

REFERENCE: Quad-Cities Nuclear Power Station, Unit 2  
Docket No. 50-265, DPR-30  
Appendix A, Sections 1.0.A.2, 3.5.B.1, 6.6.B.1.a

Dear Mr. Keppler:


The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

At 9:00 pm on July 29, 1975, during flow rate surveillance testing of the Residual Heat Removal (RHR) System Service Water Pumps, pump 2A failed to meet the Technical Specification/required flow rate of 3500 GPM at 198 PSIG. The maximum flow rate obtained was 2850 GPM at 198 PSIG. Work request 2794-75 was immediately issued for investigation and repair.

This occurrence was discussed by telephone with Mr. Knop of your office on July 30, 1975. Further information will be provided by Abnormal Occurrence Report AO 50-265/75-28 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY  
QUAD-CITIES NUCLEAR POWER STATION

  
N. J. Kalivianakis  
Station Superintendent

NJK:SRH/dkp

cc: Directorate of Licensing  
J. S. Abel

8306160307 750808  
PDR ADDCK 05000265  
S PDR

Quad-Cities Generating Station  
Post Office Box 216  
Cordova, Illinois 61242  
Telephone 309/654-2241

NJK-75-386

TELECOPY: Region III, ATTENTION: Mr. C. Feierabend  
July 30, 1975

J. Keppler, Regional Director  
Directorate of Regulatory Operations  
Region III  
U. S. NUCLEAR REGULATORY COMMISSION  
799 Roosevelt Road  
Glen Ellyn, IL 60137

REFERENCE: Quad-Cities Nuclear Power Station, Unit 2  
Docket No. 50-265, DPR-30  
Appendix A, Sections 1.0.A.2, 3.5.B.1, 6.6.B.1.a

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

At 9:00 pm on July 29, 1975, during flow rate surveillance testing of the Residual Heat Removal (RHR) System Service Water Pumps, pump 2A failed to meet the Technical Specification required flow rate of 2500 GPM at 198 PSIG. The maximum flow rate obtained was 2850 GPM at 198 PSIG. Work request 2794-75 was immediately issued for investigation and repair.

This occurrence was discussed by telephone with Mr. Knop of your office on July 30, 1975. Further information will be provided by Abnormal Occurrence Report AO 50-265/75-28 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY  
QUAD-CITIES NUCLEAR POWER STATION

*N. J. Kalivianakis*  
N. J. Kalivianakis  
Station Superintendent

NJK:SRH/akp

cc: Directorate of Licensing  
J. S. Abel

*Received 7/30/75 12:47 RD*



Commonwealth Edison  
Quad-Cities Nuclear Power Station  
Post Office Box 216  
Cordova, Illinois 61242  
Telephone 309/654-2241

NJK-75-404

August 8, 1975

Director of Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Reference: Quad-Cities Nuclear Power Station  
Docket No. 50-265, DPR-30, Unit 2  
Appendix A, Sections 1.0.A.2, 3.5.B.1, 6.6.B.1.a

Enclosed please find Abnormal Occurrence Report No. 50-265/75-28 for Quad-Cities Nuclear Power Station. This occurrence was previously reported to Region III, Directorate of Regulatory Operations by telephone on July 30, 1975 and to you and Region III, Directorate of Regulatory Operations by telecopy on July 30, 1975.

This report is submitted to you in accordance with the requirements of Technical Specification 6.6.B.1.a.

Very truly yours,

COMMONWEALTH EDISON COMPANY  
QUAD-CITIES NUCLEAR POWER STATION

N.J. Kalivianakis  
Station Superintendent

NJK/ORH/vmb

cc: Office of Inspection and Enforcement  
G.A. Abrell

COPY SENT REGION

2538