



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 15, 1984

84 MAY 17 11:07

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O' Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 84-021/0 - Fire
Door 1A320 Blocked Open to
Support Planned Maintenance
Activities
AECM-84/0124

On April 8, 1984, fire door 1A320 to the Main Steam Tunnel Room was blocked open to support planned maintenance activities. Fire watches were established in accordance with Technical Specification 3.7.7.

The door is expected to be restored by June 30, 1984. This is submitted as a Special Report pursuant to Technical Specification 6.9.2. This is a final report.

Yours truly,

L. F. Dale
Manager of Nuclear Services

EBS/SHH:tr

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. N. S. Reynolds
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8405240300 840515
PDR ADDCK 05000416
PDR
S

HDtrl

Member Middle South Utilities System

OFFICIAL COPY
IE 22.10