



Commonwealth Edison
Quad-Cities Nuclear Power Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-75-380

Telecopy: Region III, Attention: Mr. C. Feierabend

July 28, 1975



J. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station
Docket No. 50-254, DPR-29
Appendix A, Sections 1.0.A.2, 3.7.A.3.a, 6.6.B.1.a

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

At 3:00 p.m. on July 24, 1975 while performing routine quarterly surveillance on reactor building to suppression chamber vacuum breakers, pressure switch 1-1622B was found to trip 0.0126 PSI above the Technical Specification limit of 0.5 psid.

The switch was immediately recalibrated to trip at 0.451 psid.

This occurrence was discussed by telephone with Mr. Feierabend of your office on July 25, 1975. Further information will be provided by Abnormal Occurrence Report AO 50-254/75-18 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
Station Superintendent

NJK/lk

cc: Director of Office of Nuclear Reactor Regulation
J. S. Abel

8306160692 750801
PDR ADOCK 05000254
S PDR

