

LICENSEE EVENT REPORT

CONTROL BLOCK: _____

1 6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME						LICENSE NUMBER								LICENSE TYPE					EVENT TYPE					
0	1		I	L	O A D 2	0	0	-	0	0	0	0	0	-	0	0	4	1	1	1	1	0	3	
7	8	9			14	15										25	26					30	31	32

CATEGORY		REPORT TYPE	REPORT SOURCE	DOCKET NUMBER						EVENT DATE					REPORT DATE									
01	CON'T	L	L	0	5	0	-	0	2	6	5	0	4	2	7	7	6	0	5	2	7	7	6	
7	8	57	58	59	60	61					68	69						74	75					80

[illegible]

02	While performing routine monthly surveillance on PS 2-1469, ECCS Fill System	80
03	discharge header pressure switch was found to trip at 77.5 PSIG increasing which	80
04	exceeded the Technical Specification limit. The pressure switch was reset to trip	80
05	at 73.5 PSIG. This occurrence did not affect the operation of any safety systems.	80
06	A Technical Specification change request has been proposed for an increased trip	80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE					PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER				VIOLATION	
07		I	E	I	N	S	T	R	U	N	S	3	8	2	N	
7	8	9	10						17	43	44					48

CAUSE DESCRIPTION

08	(Proximate Cause: Equipment Failure) This occurrence was caused by instrument drift.	80
09	Pressure switch PS 2-1469 was provided by the Static-O-Ring Co. Model #6N-L3.	80
10		80

FACILITY STATUS		% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
11	E	0	9	1	NA		B	NA		
7	8	9	10	12	13	44	45	46	80	

FORM OF ACTIVITY RELEASED

CONTENT OF RELEASE

AMOUNT OF ACTIVITY

LOCATION OF RELEASE

PERSONNEL EXPOSURES

NUMBER			TYPE	DESCRIPTION
13	0	0	0	NA

PERSONNEL INJURIES

NUMBER			DESCRIPTION
14	0	0	NA

OFFSITE CONSEQUENCES

1	5	NA	
8	9		80

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION
16	Z	NA

PUBLICITY

8306160714 760527
PDR ADOCK 05000265
S PDR

ADDITIONAL FACTORS

18	EVENT DESCRIPTION(CONT) setting which allows normal operating pressure and still
----	--

19 | meets the intended safety function. (R0 50-265/76-6)

NAME: T. P. Joyce

PHONE: 309-654-2241 (ext. 247)



Commonwealth Edison
Quad-Cities Nuclear Power Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/654-2241

D. F. ...

NJK-76-202

May 27, 1976



J. Keppler, Regional Director
Office of Inspection and Enforcement
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station
Docket No. 50-265, DPR-30, Unit 2
Appendix A, Sections 3.5.G.2 and 6.6.B.2.a

Enclosed please find Reportable Occurrence Report No. 50-265/76-6 for
Quad-Cities Nuclear Power Station.

This report is submitted to you in accordance with the requirements of
Technical Specification 6.6.B.2.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
Station Superintendent

NJK/1k

cc: G. A. Abrell

5501

COPY SENT REGION III