



Commonwealth Edison
Quad-Cities Nuclear Power Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-76-110

Telecopy: Region III, Attention: Mr. C. Feierabend

March 30, 1976

J. Keppler, Regional Director
Office of Inspection and Enforcement
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 2
Docket No. 50-265, DPR-30
Appendix A, Sections 3.7.A.1.b, 6.6.B.1.b

Dear Mr. Keppler:


The purpose of this letter is to provide you with notification of a Reportable Occurrence as required by Technical Specification 6.6.B.1 within 24 hours of the occurrence.

On March 30, 1976, the Suppression Chamber water level instrumentation was found to be miscalibrated by Instrument Maintenance personnel performing a routine surveillance. Prior to the instruments' recalibration it indicated that the Suppression Chamber level was -0.8 inches while actually the Suppression Chamber level was -2.8 inches. The Suppression Chamber water level was immediately returned to normal.

This occurrence was discussed by telephone with Mr. R. Knop of your office on March 30, 1976. Further information will be provided by Reportable Occurrence Report RO 50-265/76-4 which will be submitted within 14 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION


N. J. Kalivianakis
Station Superintendent

NJK/GJK/1k

cc: G. A. Abrell

8306160723 760413
PDR ADOCK 05000265
S PDR

rec'd 3/13 3/30 doc

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

Incident Notification From: Commonwealth Edison Company 50-265
(Licensee & Docket No. (or License No.))

Transmittal Date: April 14, 1976 Quad-Cities Unit #2

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
Licensing(4)
DR Central Files
IE Files

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
L:D/D for Fuels & Materials
DR Central Files
IE Files