



Commonwealth Edison  
Quad-Cities Generating Station  
Post Office Box 216  
Cordeiro, Illinois 61242  
Telephone 309/654-2241

HJK-76-9

Telecopy: Region III, Attention: Mr. C. Feierabend

January 9, 1976

J. Keppler, Regional Director  
Office of Inspection and Enforcement  
Region III  
U. S. Nuclear Regulatory Commission  
759 Roosevelt Road  
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 1  
Docket No. 50-254, DPR-29  
Appendix A, Section 6.6.B.1.c

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of a Reportable Occurrence as required by Technical Specification 6.6.B.1 within 24 hours of the occurrence.

With Unit 1 in the cold shutdown condition, weld examinations were conducted on the reactor recirculation discharge bypass lines. On January 8, 1976, crack indications were confirmed on the "A" loop at the valve-to-pipe junction and on the "B" loop at a pipe-to-pipe junction. Both crack indications were on the side of the bypass valve that cannot be isolated and were in heat affected zones. Plans concerning the repairs to be made are incomplete at this time.

This occurrence was discussed by telephone with Mr. Feierabend of your office on January 8, 1976. Further information will be provided by Reportable Occurrence Report RO 50-254/76-4 which will be submitted within 14 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY  
QUAD-CITIES NUCLEAR POWER STATION

R. J. Kalivianakis  
Station Superintendent

RJK/HGL/L

cc: E. A. Abrell

1/9/76 12<sup>00</sup> p  
8306160729 760109  
PDR ADOCK 05000254  
S PDR

20-254

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLEN, ILLINOIS 60137

Incident Notification From: Commonwealth Edison Company 50-254  
(Licensee & Docket No. (or License No.))

Transmittal Date : January 16, 1976 Quad-Cities Unit #1

Distribution:

IE Chief, FOSB  
IE Chief, FC&EB  
IE:HQ(4)  
Licensing(4)  
DR Central Files  
IE Files

Distribution:

IE Chief, FSOB  
IE Chief, FC&EB  
IE:HQ(4)  
L:D/D for Fuels & Materials  
DR Central Files  
IE Files

