



RR 2 NP-08-84-03
E 2.40.1.1.1
G84 295AL

May 15, 1984

Ohio Environmental Protection Agency
Northwest District Office
1035 Devlac Grove Road
Bowling Green, Ohio 43402
ATTN: Mr. Bruce Dunlavy

Subject: Noncompliance notification for NPDES Permit No. 2IB00011, for the
Davis-Besse Nuclear Power Station

Dear Mr. Dunlavy:

In accordance with the requirements of Part A.2 of NPDES Permit No. 2IB00011
for the Davis-Besse Nuclear Power Station, we wish to notify you of a recent
noncompliance condition.

The Total Suspended Solids daily maximum limit was exceeded at Outfall No. 002
(Area Runoff) on May 14, 1984. The daily maximum limit is 50 mg/l for Total
Suspended Solids. The daily reading for Total Suspended Solids at Outfall 002
was 86.8 mg/l on May 14, 1984.

<u>Date</u>	<u>Outfall</u>	<u>Parameter</u>	<u>Analysis</u>
May 14, 1984	002	Total Suspended Solids	86.8 mg/l

Winds coming from the west and southwest continue to kick up solids from the
pond bottom near Outfall 002. Outfall 002 is located at the east side of the
pond and is therefore, particularly sensitive to persistent winds blowing from
the west. Heavy rainfall on Sunday, May 13, 1984 may have contributed to run-
off into the pond.

It was noted during the water sampling on Monday, May 14, 1984 that a large
population of carp had infiltrated this pond for spawning. These carp were
active in disturbing the pond bottom near Outfall 002 while attempting to
spawn.

If you have any questions, please contact Kelly Nash at (419) 259-5000, Ext. 711.

Yours truly,

Terry D. Murray
Terry D. Murray
Station Superintendent
Davis-Besse Nuclear Power Station

bcc: R. P. Crouse
J. E. Sullivan
C. Daft
E. C. Novak
J. F. Helle
J. J. Pfeiffer
J. Scott-Wasilk
R. J. Scott
D. W. Briden
L. Grime
J. Stolz, NRR NRC
W. Rogers, NRC Resident In

TDM/KLN/ym1

8405250101 840515
PDR ADDCK 05000346
S PDR

IE23
1/0