



Duquesne Light

Nuclear Construction Division
Robinson Plaza, Building 2, Suite 210
Pittsburgh, PA 15205

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

2NRC-4-050
(412) 787-5141
(412) 923-1960
Telecopy (412) 787-2629
May 3, 1984

ATTENTION: Mr. Richard W. Starostecki
Division of Project and Resident Programs

SUBJECT: Beaver Valley Power Station - Unit No. 2
Docket No. 50-412
USNRC IE Inspections 50-412/82-01 and 82-11
Meeting to Discuss:
1) Violation 82-01-01: "ASME III Class 3 'Notch' Condition"
2) Violation 83-11-01: "Post Weld Heat Treatment"


Gentlemen:

In discussion with Mr. Jack Durr, NRC Region I, and Mr. S. D. Hall, Beaver Valley Power Station Unit No. 2 (BVPS-2), on April 19, 1984, it is understood that a meeting will be held at BVPS-2 site at BVPS-2's request. The meeting is to be held on May 22, 1984, at 10:00 a.m. in the QA Conference Room. The purpose of the meeting is to discuss Violation 82-01-01, "ASME III Class 3 'Notch' Condition," and Violation 83-11-01, "Post Weld Heat Treatment." The discussion on Violation 82-01-01 will focus on the stress intensification factor used in close proximity to the notch effect. BVPS-2's A/E (SWEC) will show samples of the stress analysis used and the stress results which were below the stress allowables.

The discussion concerning Violation 83-11-01 will address the requirement of actual thickness versus nominal/specified thickness for post weld "heat-up rates" and "time-required-at-temperature" for post weld heat treatment. SWEC will present the results of an evaluation on the acceptability of using the specified minimum wall thickness as opposed to actual thickness used in the calculations made for post weld heat treatment requirements.

It is expected that the results of this meeting will provide the NRC the necessary information to closeout Violation 82-01-01 and 83-11-01.

DUQUESNE LIGHT COMPANY

By 
E. J. Woolever
Vice President

SDH/wjs

cc: NRC Document Control Desk
Mr. G. Walton, NRC Resident Inspector
Mr. M. Lacitra, Project Manager

8405250118 840521
PDR ADOCK 05000412
PDR
Q

United States Nuclear Regulatory Commission
Mr. Richard W. Starostecki
Page 2

SDH/wjs
NR/NRC/IEI8201

J. J. Carey
bcc: C. E. Ewing
T. D. Jones
H. M. Siegel
R. J. Swiderski
J. F. Zagorski
L. E. Arch
R. Coupland
D. H. Williams
M. Zaki
C. R. Bishop
P. RaySircar (S&W)(3)
J. Sutton (S&W)
T. J. Lex (W)(4)
NCD File
NRC Inspection 82-01 File
NRC Inspection 83-11 File