



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

ROGER W. KOBER
VICE PRESIDENT
ELECTRIC & STEAM PRODUCTION

TELEPHONE
AREA CODE 716 546-2700



May 21, 1984

Dr. Thomas E. Murley, Regional Administrator
U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Subject: IE Bulletin No. 84-02
Failures of General Electric Type HFA Relays in use
in Class 1E Safety Systems.
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Dr. Murley:

In response to NRC IE Bulletin No. 84-02, there are no General Electric Type HFA relays used in Class 1E Safety Systems at Ginna Station. Westinghouse BF (ac) and BFD (dc) relays are used in these applications at Ginna. Westinghouse has experienced similar problems with their relays that resulted in several Westinghouse Technical Bulletins, NRC IE Circulars, and NRC IE Bulletins. Ginna Station is current with the latest received vendor recommendations.

This response required two staff hours for review and preparation of the written report. No radiation exposure was incurred.

Very truly yours,

R. W. Kober

Subscribed and sworn to me
on this 21st day of May 1984.

LYNN I. HAUCK

NOTARY PUBLIC, State of N.Y., Monroe County
My Commission Expires March 30, 1985

8405250217 840521
PDR ADOCK 05000244
Q PDR

IE11
10