



Commonwealth Edison
Quad-Cities Generating Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/654-2241

5-5-74
#5225

NJK-75-226

TELECOPY: Region III, Attention: Mr. C. Feierabend

April 28, 1975



J. Keppler, Regional Director
Directorate of Regulatory Operations - Region III
U. S. NUCLEAR REGULATORY COMMISSION
799 Roosevelt Road
Glen Elly, IL 60137

REFERENCE: Quad-Cities Nuclear Power Station, Unit 2
Docket No. 50-265, DPR-30
Appendix A, Sections 1.0.A.2, 3.6.C.3, 6.6.B.1.a

Dear Mr. Keppler:


The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

During the start-up test program on Unit 2 following the cycle 1 refuel outage, the reactor was shutdown to change control rod patterns. Start-up commenced at 7:02 p.m. on April 26, 1975. An earlier (5 p.m.) sample of reactor coolant showed conductivity of 8.65 umho and chloride concentration of 0.295 ppm, thus exceeding Technical Specification 3.6.C.3. Upon realization of this occurrence, an orderly shutdown was commenced with the reactor subcritical at 8:32 p.m. It is suspected that the high readings were caused by a condenser tube leak. Present plans are to identify and correct the tube leaks during the present shutdown. Latest reactor coolant samples show the chloride concentration to be .049 ppm.

This occurrence was discussed by telephone with Mr. Feierabend of your office on April 27, 1975. Further information will be provided by Abnormal Occurrence Report AO 50-265/75-15 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION


N. J. Kalivianakis
Station Superintendent

NJK:CWS/dkp

8306170141 750505
PDR ADOCK 05000265
S PDR

cc: Directorate of Licensing
J. S. Abel

4859



Commonwealth Edison
Quad-Cities Generating Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/654-2241

File

NJK-75-226

TELECOPY: Region III, Attention: Mr. C. Feierabend

April 28, 1975

J. Keppler, Regional Director
Directorate of Regulatory Operations - Region III
U. S. NUCLEAR REGULATORY COMMISSION
799 Roosevelt Road
Glen Elly, IL 60137

REFERENCE: Quad-Cities Nuclear Power Station, Unit 2
Docket No. 50-265, DPR-30
Appendix A, Sections 1.0.A.2, 3.6.C.3, 6.6.B.1.a

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

During the start up test program on Unit 2 following the cycle 1 refuel outage, the reactor was shutdown to change control rod patterns. Start-up commenced at 7:02 p.m. on April 26, 1975. An earlier (5 p.m.) sample of reactor coolant showed conductivity of 8.65 umho and chloride concentration of 0.295 ppm, thus exceeding Technical Specification 3.6.C.3. Upon realization of this occurrence, an orderly shutdown was commenced with the reactor subcritical at 8:32 p.m. It is suspected that the high readings were caused by a condenser tube leak. Present plans are to identify and correct the tube leaks during the present shutdown. Latest reactor coolant samples show the chloride concentration to be .049 ppm.

This occurrence was discussed by telephone with Mr. Feierabend of your office on April 27, 1975. Further information will be provided by Abnormal Occurrence Report AO 50-265/75-15 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
N. J. Kalivianakis
Station Superintendent

NJK:CWS/dkp

cc: Directorate of Licensing
J. S. Abel

Dupe of previous
8306170141

4859