



Commonwealth Edison
Quad-Cities Nuclear Power Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/654-2241



NJK-75-298

Telecopy: Region III, Attention: Mr. C. Feierabend

May 29, 1975

J. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 1
Docket No. 50-254, DPR-29
Appendix A, Sections 1.0.A.2, 3.1, 6.6.B.1.a

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.


At 11:00 a.m. on May 28, 1975, while performing routine surveillance testing on the electrohydraulic control system low pressure sensors, pressure switch 1-5600-PS-3 tripped at 890 PSIG, which is below the Technical Specification limit of ≥ 900 PSIG. The switch was then recalibrated to 935 PSIG.

Due to the frequency of setpoint drift beyond the limits for these switches, the surveillance frequency has been increased from quarterly to weekly and an action item has been issued to the station Nuclear Engineering Department to investigate possible replacement switches.

This occurrence was discussed by telephone with Mr. Feierabend of your office on May 29, 1975. Further information will be provided by Abnormal Occurrence Report AO 50-254/75-15 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION


N. J. Kalivianakis
Station Superintendent

NJK/SRH/IK

cc: Director of Office of Nuclear Reactor Regulation
J. S. Abel

8306170149 750606
PDR ADOCK 05000254
S PDR