



Commonwealth Edison
Quad-Cities Nuclear Power Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/654-2241



NJK-75-289

Telecopy: Region III, Attention: Mr. C. Feierabend

May 23, 1975

J. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 1
Docket No. 50-254, DPR-29
Appendix A, Sections 1.0.A.8, 6.6.B.1.a

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

On May 22, 1975, while discharging the B Floor Drain Sample Tank, the operator was attempting to transfer the contents of the Waste Collector Tank into the Floor Drain Surge Tank. Due to a valving error he was instead transferring the contents into the tank being discharged. When the valving error was discovered it was corrected immediately and the discharge was ceased. The activity of the water being transferred was determined to be 3.25×10^{-6} pci/ml. The activity of the water being discharged had been determined to be 7.35×10^{-4} pci/ml. Thus, the water inadvertently transferred into the sample tank was actually diluting the water being discharged.

This occurrence was discussed by telephone with Mr. Knop of your office on May 23, 1975. Further information will be provided by Abnormal Occurrence Report AO 50-254/75-14 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

John J. Kalivianakis
N. J. Kalivianakis
Station Superintendent

NJK/RAR/lk

cc: Directorate of Licensing
J. S. Abel

8306170154 750530
PDR ADOCK 05000254
S PDR

COPY SENT REGION *III*