



Commonwealth Edison  
Quad-Cities Generating Station  
Post Office Box 218  
Cordova, Illinois 61242  
Telephone 309/654-2241

NJK-75-266

Telecopy: Region III, Attention: Mr. C. Feierabend

May 8, 1975

J. Keppler, Regional Director  
Directorate of Regulatory Operations  
Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
San Elin, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 1  
Docket No. 50-254, DPP-29  
Appendix A, Sections 1.0.A.2, 3.5-C, 6.6.B.1.a

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

While-attempting to run surveillance tests on the Unit One HPCI system, it was discovered that the motor speed changes would not operate. Since the RCIC system was inoperable an orderly shutdown was initiated at the rate of 10 MWe/hr.

This occurrence was discussed by telephone with Mr. Feierabend of your office on May 8, 1975. Further information will be provided by Abnormal Occurrence Report AO 50-254/75-13 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY  
QUAD-CITIES NUCLEAR POWER STATION

*H. J. Kalivianakis*  
H. J. Kalivianakis  
Station Superintendent

8306170165 750513  
PDR ADOCK 05000254  
S PDR

NJK/RAR/vmm

cc: Directorate of Licensing  
J. S. Abel