



Commonwealth Edison
Quad-Cities Generating Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-75-201

Telecopy: Region III, Attention: Mr. C. Feierabend

April 16, 1975

J. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 1
Docket No. 50-254, DPR-29
Appendix A, Sections 1.0.A.2, 3.1, 6.6.B.1.a

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

At 5:00 p.m. on April 14, 1975, with Unit 1 operating at 800 MWe, while performing surveillance testing on the EHC fluid low pressure sensors, it was discovered that three of the four pressure switches tripped below the Technical Specification setpoint of ≥ 900 psig. The switches were recalibrated to ≥ 930 psig.

Due to the inordinate amount of setpoint drift experienced with these pressure switches, the surveillance frequency is being increased to weekly and an action item is being submitted to the engineering department to investigate and procure a more reliable type of pressure switch.

This occurrence was discussed by telephone with Mr. Feierabend of your office on April 15, 1975. Further information will be provided by Abnormal Occurrence Report AO 50-254/75-8 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

M. J. Kalivianakis
Station Superintendent

NJK/SRH/jeh

cc: Directorate of Licensing
J. S. Abel

4457

8306170441 750421
PDR ADOCK 05000265
S PDR