

CP&L

Carolina Power & Light Company

H. B. ROBINSON STEAM ELECTRIC PLANT
Post Office Box 790
Hartsville, South Carolina 29552

IE FILE COPY

January 26, 1977

Robinson File No. 2-0-4-a-1

Mr. Norman C. Moseley, Director
Directorate of Regulatory Operations
U. S. Nuclear Regulatory Commission
Region II, Suite 818
230 Peachtree Street, N.W.
Atlanta, Georgia 30303


Dr. Ernst Volgenau, Director
U. S. Nuclear Regulatory Commission
Directorate of Regulatory Operations
Washington, D. C. 20555

Dear Sirs:

In accordance with section 6.9.2.a.2 of the Technical Specifications, the following Reportable Occurrence is submitted:

On January 25, 1977 following a plant trip, with the reactor subcritical the flow paths from the boric acid tanks were made inoperable for the repair of valves CVC 348 and CVC 375. This is a violation of Technical Specification 3.2.2.d. This was reported to Mr. Harold Banks of Carolina Power and Light Company on January 25, 1977 and Mr. Bud Epps of the Nuclear Regulatory Commission on January 26, 1977.

Yours very truly,



Jack B. McGirt, Manager
H. B. Robinson SEG Plant

REM/ld