



# Telegram

8

VEA40 1(2043)(1-03223 103(25)PD 11/20/72 2039

IGS IPMVEIA MVN

ZCZC 00221 TDVE MORRIS ILL 120 11-20/3 15P CST

PMS MR BOYCE ORIER DIR DIVN OF COMPLIANCE REGION 3 WUX MACHINE

US ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD

GLEN ELLYN ILL 60137

SUBJECT : DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3

THIS WILL CONFIRM A CONVERSATION WITH MR H DANCE OF YOUR OFFICE AT 1100 HOURS THIS DATE CONCERNING REACTORS LOW PRESSURE SWITCHES BEING OUT OF CALIBRATION. ON 11/19/72 WHILE UNIT 3 WAS SHUT DOWN, A CALIBRATION WAS MADE ON MAIN STEAM LINE LOW PRESSURE SWITCHES. CABLE 3.2.1 OF THE TECHNICAL SPECIFICATIONS STATE THAT THE TRIP LEVEL SETTING ON THESE SWITCHES SHOULD BE EQUAL TO OR GREATER THAN 850 PSIG. ALL FOUR PRESSURE SWITCHES HAD TRIP SETTINGS BELOW 850 PSIG. PRESSURE SWITCHES 3-261-30A AND 30B HAD SETTING OF 845 AND 848 PSIG. PRESSURE SWITCHES 3-261-30C AND 30D

SF-1201 (RS)

IN THE FUTURE THE "AS LEFT" CALIBRATION SETTING ON THESE SWITCHES HAS BEEN CHANGED FROM 855 PLUS OR MINUS PSIG TO 866 PLUS OR MINUS 4PSIG.

W P WORDEN SUPERINTENDENT COMMONWEALTH EDISON  
DRESDEN NUCLEAR POWERSTATION RR 1 MORRIS ILLINOIS

8306230239 721129  
PDR ADOCK 05000249  
S PDR

## TELEGRAMS (OTHER THAN MONEY ORDERS)

Is PHYSICAL DELIVERY requested? \_\_\_\_\_ (YES-AGENT, NO-ADDRESSEE)  
AGENT SECTION ADDRESSSEE SECTION  
Nbr. & Name \_\_\_\_\_ Nbr. 362-858-7660  
Date dtd 11/21 Time dtd 8:54 To 139 BY CH  
To be mailed or filed mail  
Attempts to deliver (Indicate DA or BY) \_\_\_\_\_

50-249  
ing.

SF-1201 (RS-69)